

2017 Fluoride Results

The Lakeshore, Lucknow and Ripley Water Systems have elevated, naturally occurring fluoride which can have an effect on your dental health. Please review the attached fact sheet for a better understanding. This is not considered a health hazard.

Lakeshore Drinking Water System:

Blairs Grove - 2.20 mg/L

Huronville S - 2.24 mg/L

Murdoch Glen - 2.14 mg/L

Point Clark - 2.20 mg/L

Lucknow Drinking Water System:

Lucknow #4 - 1.75 mg/L

Lucknow #5 - 1.78 mg/L

Ripley Drinking Water System

Wells #1 & 2 combined - 2.10 mg/L