

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

28-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 25 February 2025
LR Report: CA21160-FEB25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				26-Feb-25	26-Feb-25	26-Feb-25
2: Analysis Start Time				09:55	09:55	09:20
3: Analysis Completed Date				28-Feb-25	28-Feb-25	28-Feb-25
4: Analysis Completed Time				10:41	10:41	10:41
5: MAC		---	---	0	0	---
6: RW RW5-Murdoch Glen RW-Well 2	24-Feb-25 13:34	7.8	---	0	0	---
7: TW TW4-Murdoch Glen TW	24-Feb-25 13:31	7.8	2.52	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

28-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 25 February 2025
LR Report: CA21161-FEB25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				26-Feb-25	26-Feb-25	26-Feb-25
2: Analysis Start Time				09:55	09:55	09:20
3: Analysis Completed Date				28-Feb-25	28-Feb-25	28-Feb-25
4: Analysis Completed Time				10:41	10:41	10:41
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	24-Feb-25 13:47	7.8	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	24-Feb-25 13:49	7.8	---	0	0	---
8: TW TW3-Point Clark TW	24-Feb-25 13:30	7.8	1.65	0	0	< 10
9: DW DW-Point Clark Community Centre	24-Feb-25 14:14	7.8	1.37	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

28-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 25 February 2025
 LR Report: CA21162-FEB25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				26-Feb-25	26-Feb-25	26-Feb-25
2: Analysis Start Time				09:55	09:55	09:20
3: Analysis Completed Date				28-Feb-25	28-Feb-25	28-Feb-25
4: Analysis Completed Time				10:41	10:41	10:41
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	24-Feb-25 14:08	7.8	---	0	0	---
7: TW TW2-Huronville South TW	24-Feb-25 14:05	7.8	1.53	0	0	< 10
8: DW DW-Inverlyn Club House	24-Feb-25 14:22	7.8	1.35	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

28-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 25 February 2025
LR Report: CA21163-FEB25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				26-Feb-25	26-Feb-25	26-Feb-25
2: Analysis Start Time				09:55	09:55	09:20
3: Analysis Completed Date				28-Feb-25	28-Feb-25	28-Feb-25
4: Analysis Completed Time				10:41	10:41	10:41
5: MAC		---	---	0	0	---
6: DW DW-Chem Shed	24-Feb-25 14:25	7.8	1.41	0	0	< 10
7: DW DW-Amberly Store (ACW)	24-Feb-25 13:05	7.8	1.61	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

24-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 19 February 2025
 LR Report: CA21029-FEB25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	20-Feb-25	20-Feb-25	20-Feb-25
2: Analysis Start Time		---	---	12:55	12:55	12:25
3: Analysis Completed Date		---	---	24-Feb-25	24-Feb-25	24-Feb-25
4: Analysis Completed Time		---	---	10:15	10:15	10:15
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	19-Feb-25 09:23	10.8	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	19-Feb-25 09:01	10.8	---	0	0	---
8: TW TW3-Point Clark TW	19-Feb-25 09:04	10.8	1.02	0	0	< 10
9: DW DW-Point Clark Community Centre	19-Feb-25 09:38	10.8	1.77	0	0	< 10
10: RW RW2-Huronville South RW-Well 1	19-Feb-25 10:35	10.8	---	0	0	---
11: TW TW2-Huronville South TW	19-Feb-25 10:31	10.8	1.53	0	0	< 10
12: DW DW-Inverlyn Club House	19-Feb-25 10:49	10.8	1.24	0	0	< 10
13: RW RW5-Murdoch Glen RW-Well 2	19-Feb-25 10:15	10.8	---	0	0	---
14: TW TW4-Murdoch Glen TW	19-Feb-25 10:10	10.8	2.40	0	0	< 10
15: DW DW-Chem Shed	19-Feb-25 09:49	10.8	1.81	0	0	< 10
16: DW DW-Amberly Store (ACW)	19-Feb-25 08:45	10.8	1.82	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21029-FEB25

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

14-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 11 February 2025
 LR Report: CA20724-FEB25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	12-Feb-25	12-Feb-25	12-Feb-25
2: Analysis Start Time		---	---	09:20	09:20	09:05
3: Analysis Completed Date		---	---	14-Feb-25	14-Feb-25	14-Feb-25
4: Analysis Completed Time		---	---	10:45	10:45	10:45
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	10-Feb-25 14:12	5.6	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	10-Feb-25 14:14	5.6	---	0	0	---
8: TW TW3-Point Clark TW	10-Feb-25 13:55	5.6	2.64	0	0	< 10
9: DW DW-Point Clark Community Centre	10-Feb-25 14:29	5.6	1.61	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

14-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 11 February 2025
 LR Report: CA20725-FEB25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	12-Feb-25	12-Feb-25	12-Feb-25
2: Analysis Start Time		---	---	09:20	09:20	09:05
3: Analysis Completed Date		---	---	14-Feb-25	14-Feb-25	14-Feb-25
4: Analysis Completed Time		---	---	10:46	10:46	10:46
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW - Well 3	10-Feb-25 15:06	5.6	---	0	0	---
7: TW TW1-Blairs Grove TW	10-Feb-25 14:59	5.6	2.42	0	0	10
8: DW DW-Chem Shed	10-Feb-25 15:16	5.6	2.03	0	0	< 10
9: DW DW-Elliots Construction	10-Feb-25 13:35	5.6	1.80	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

14-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 11 February 2025
 LR Report: CA20726-FEB25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	12-Feb-25	12-Feb-25	12-Feb-25
2: Analysis Start Time		---	---	09:20	09:20	09:05
3: Analysis Completed Date		---	---	14-Feb-25	14-Feb-25	14-Feb-25
4: Analysis Completed Time		---	---	10:46	10:46	10:46
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	10-Feb-25 16:11	5.6	---	0	0	---
7: TW TW2-Huronville South TW	10-Feb-25 16:08	5.6	1.61	0	0	< 10
8: DW DW-Inverlyn Club House	10-Feb-25 16:19	5.6	1.21	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


 Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

14-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 11 February 2025
 LR Report: CA20727-FEB25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	12-Feb-25	12-Feb-25	12-Feb-25
2: Analysis Start Time		---	---	09:20	09:20	09:05
3: Analysis Completed Date		---	---	14-Feb-25	14-Feb-25	14-Feb-25
4: Analysis Completed Time		---	---	10:46	10:46	10:46
5: MAC		---	---	0	0	---
6: RW RW5-Murdoch Glen RW-Well 2	10-Feb-25 15:44	5.6	---	0	0	---
7: TW TW4-Murdoch Glen TW	10-Feb-25 15:34	5.6	2.50	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

07-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 04 February 2025
 LR Report: CA20189-FEB25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	05-Feb-25	05-Feb-25	05-Feb-25
2: Analysis Start Time		---	---	10:00	10:00	09:50
3: Analysis Completed Date		---	---	07-Feb-25	07-Feb-25	07-Feb-25
4: Analysis Completed Time		---	---	09:59	09:59	09:59
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW - Well 3	03-Feb-25 13:47	8.0	---	0	0	---
7: TW TW1-Blairs Grove TW	03-Feb-25 13:44	8.0	1.62	0	0	< 10
8: DW DW-Chem Shed	03-Feb-25 13:28	8.0	1.44	0	0	< 10
9: DW DW-Courtney Subdivision	03-Feb-25 12:30	8.0	1.45	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

07-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 04 February 2025
LR Report: CA20190-FEB25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	05-Feb-25	05-Feb-25	05-Feb-25
2: Analysis Start Time		---	---	10:00	10:00	09:50
3: Analysis Completed Date		---	---	07-Feb-25	07-Feb-25	07-Feb-25
4: Analysis Completed Time		---	---	09:59	09:59	09:59
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	03-Feb-25 12:44	8.0	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	03-Feb-25 12:46	8.0	---	0	0	---
8: TW TW3-Point Clark TW	03-Feb-25 12:56	8.0	2.32	0	0	< 10
9: DW DW-Point Clark Community Centre	03-Feb-25 13:14	8.0	1.47	0	0	10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

07-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 04 February 2025
LR Report: CA20191-FEB25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	05-Feb-25	05-Feb-25	05-Feb-25
2: Analysis Start Time		---	---	10:00	10:00	09:50
3: Analysis Completed Date		---	---	07-Feb-25	07-Feb-25	07-Feb-25
4: Analysis Completed Time		---	---	09:59	09:59	09:59
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	03-Feb-25 17:36	8.0	---	0	0	---
7: TW TW2-Huronville South TW	03-Feb-25 17:45	8.0	1.55	0	0	< 10
8: DW DW-Inverlyn Club House	03-Feb-25 18:09	8.0	1.30	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

07-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 04 February 2025
LR Report: CA20192-FEB25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	05-Feb-25	05-Feb-25	05-Feb-25
2: Analysis Start Time		---	---	10:00	10:00	09:50
3: Analysis Completed Date		---	---	07-Feb-25	07-Feb-25	07-Feb-25
4: Analysis Completed Time		---	---	09:59	09:59	09:59
5: MAC		---	---	0	0	---
6: RW RW5-Murdoch Glen RW-Well 2	03-Feb-25 14:49	8.0	---	0	0	---
7: TW TW4-Murdoch Glen TW	03-Feb-25 14:41	8.0	2.54	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

31-January-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 28 January 2025
 LR Report: CA21186-JAN25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	29-Jan-25	29-Jan-25	29-Jan-25
2: Analysis Start Time		---	---	09:40	09:40	09:30
3: Analysis Completed Date		---	---	31-Jan-25	31-Jan-25	31-Jan-25
4: Analysis Completed Time		---	---	09:47	09:47	09:47
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	27-Jan-25 14:50	6.8	---	0	0	---
7: TW TW2-Huronville South TW	27-Jan-25 14:53	6.8	1.52	0	0	< 10
8: DW DW-Inverlyn Club House	27-Jan-25 15:05	6.8	1.42	0	0	< 10
9: RW RW1-Blairs Grove RW - Well 3	27-Jan-25 14:06	6.8	---	0	0	---
10: TW TW1-Blairs Grove TW	27-Jan-25 14:12	6.8	1.61	0	0	< 10
11: DW DW-Chem Shed	27-Jan-25 13:56	6.8	1.45	0	0	< 10
12: DW DW-Elliots Construction	27-Jan-25 13:10	6.8	1.39	0	0	< 10
13: RW RW3-Point Clark RW-Well 2	27-Jan-25 13:32	6.8	---	0	0	---
14: RW RW4-Point Clark RW-Well 3	27-Jan-25 13:30	6.8	---	0	0	---
15: TW TW3-Point Clark TW	27-Jan-25 13:28	6.8	1.46	0	0	< 10
16: DW DW-Point Clark Community Centre	27-Jan-25 13:45	6.8	1.49	0	0	< 10
17: RW RW5-Murdoch Glen RW-Well	27-Jan-25 14:35	6.8	---	0	0	---
18: TW TW4-Murdoch Glen TW	27-Jan-25 14:32	6.8	2.34	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Cristal Schuster
 Project Specialist-London,

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

24-January-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 21 January 2025
 LR Report: CA20911-JAN25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	22-Jan-25	22-Jan-25	22-Jan-25
2: Analysis Start Time		---	---	10:30	10:30	09:50
3: Analysis Completed Date		---	---	24-Jan-25	24-Jan-25	24-Jan-25
4: Analysis Completed Time		---	---	10:39	10:39	10:39
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	20-Jan-25 13:37	4.9	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	20-Jan-25 14:04	4.9	---	0	0	---
8: TW TW3-Point Clark TW	20-Jan-25 13:31	4.9	1.55	0	0	< 10
9: DW DW-Point Clark Community Centre	20-Jan-25 14:37	4.9	1.45	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21186-JAN25

Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

24-January-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 21 January 2025
 LR Report: CA20912-JAN25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	22-Jan-25	22-Jan-25	22-Jan-25
2: Analysis Start Time		---	---	10:30	10:30	09:50
3: Analysis Completed Date		---	---	24-Jan-25	24-Jan-25	24-Jan-25
4: Analysis Completed Time		---	---	10:40	10:40	10:40
5: MAC		---	---	0	0	---
6: RW RW5-Murdoch Glen RW-Well	20-Jan-25 16:29	4.9	---	0	0	---
7: TW TW4-Murdoch Glen TW	20-Jan-25 16:22	4.9	2.20	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

24-January-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 21 January 2025
 LR Report: CA20913-JAN25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	22-Jan-25	22-Jan-25	22-Jan-25
2: Analysis Start Time		---	---	10:30	10:30	09:50
3: Analysis Completed Date		---	---	24-Jan-25	24-Jan-25	24-Jan-25
4: Analysis Completed Time		---	---	10:40	10:40	10:40
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW-Well 3	20-Jan-25 17:04	4.9	---	0	0	---
7: TW TW1-Blairs Grove TW	20-Jan-25 17:02	4.9	1.63	0	0	< 10
8: DW DW-Chem Shed	20-Jan-25 11:53	4.9	1.46	0	0	< 10
9: DW DW-Elliots Construction	20-Jan-25 13:20	4.9	1.51	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


 Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

24-January-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 21 January 2025
 LR Report: CA20914-JAN25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	22-Jan-25	22-Jan-25	22-Jan-25
2: Analysis Start Time		---	---	10:30	10:30	09:50
3: Analysis Completed Date		---	---	24-Jan-25	24-Jan-25	24-Jan-25
4: Analysis Completed Time		---	---	10:42	10:42	10:42
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	20-Jan-25 16:40	4.9	---	0	0	---
7: TW TW2-Huronville South TW	20-Jan-25 16:36	4.9	1.50	0	0	< 10
8: DW DW-Inverlyn Club House	20-Jan-25 16:51	4.9	1.43	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

21-January-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 14 January 2025
 LR Report: CA20566-JAN25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Draft Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	15-Jan-25	15-Jan-25	15-Jan-25
2: Analysis Start Time		---	---	09:10	09:10	09:00
3: Analysis Completed Date		---	---	17-Jan-25	17-Jan-25	17-Jan-25
4: Analysis Completed Time		---	---	10:29	10:29	10:29
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	13-Jan-25 16:10	6.0	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	13-Jan-25 16:05	6.0	---	0	0	---
8: TW TW3-Point Clark TW	13-Jan-25 16:02	6.0	1.40	0	0	< 10
9: DW DW-Point Clark Community Centre	13-Jan-25 15:22	6.0	1.45	0	0	10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

17-January-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 14 January 2025
 LR Report: CA20563-JAN25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	15-Jan-25	15-Jan-25	15-Jan-25
2: Analysis Start Time		---	---	09:10	09:10	09:00
3: Analysis Completed Date		---	---	17-Jan-25	17-Jan-25	17-Jan-25
4: Analysis Completed Time		---	---	10:28	10:28	10:28
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW - Well 3	13-Jan-25 15:10	6.0	---	0	0	---
7: TW TW1-Blairs Grove TW	13-Jan-25 15:07	6.0	1.61	0	0	< 10
8: DW DW-Chem Shed	13-Jan-25 14:46	6.0	1.38	0	0	< 10
9: DW DW-Elliots Construction	13-Jan-25 15:48	6.0	1.30	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

17-January-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 14 January 2025
 LR Report: CA20564-JAN25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	15-Jan-25	15-Jan-25	15-Jan-25
2: Analysis Start Time		---	---	09:10	09:10	09:00
3: Analysis Completed Date		---	---	17-Jan-25	17-Jan-25	17-Jan-25
4: Analysis Completed Time		---	---	10:29	10:29	10:29
5: MAC		---	---	0	0	---
6: RW RW5-Murdoch Glen RW-Well	13-Jan-25 14:26	6.0	---	0	0	---
7: TW TW4-Murdoch Glen TW	13-Jan-25 14:13	6.0	1.55	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

17-January-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 14 January 2025
 LR Report: CA20565-JAN25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	15-Jan-25	15-Jan-25	15-Jan-25
2: Analysis Start Time		---	---	09:10	09:10	09:00
3: Analysis Completed Date		---	---	17-Jan-25	17-Jan-25	17-Jan-25
4: Analysis Completed Time		---	---	10:29	10:29	10:29
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	13-Jan-25 13:58	6.0	---	0	0	---
7: TW TW2-Huronville South TW	13-Jan-25 13:53	6.0	1.57	0	0	< 10
8: DW DW-Inverlyn Club House	13-Jan-25 13:43	6.0	1.29	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

13-January-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 08 January 2025
 LR Report: CA20301-JAN25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	08-Jan-25	08-Jan-25	08-Jan-25
2: Analysis Start Time		---	---	12:45	12:45	12:05
3: Analysis Completed Date		---	---	10-Jan-25	10-Jan-25	10-Jan-25
4: Analysis Completed Time		---	---	11:12	11:12	11:12
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW-Well 3	06-Jan-25 15:00	8.8	---	0	0	---
7: TW TW1-Blairs Grove TW	06-Jan-25 14:56	8.8	1.61	0	0	< 10
8: DW DW-Chem Shed	06-Jan-25 14:41	8.8	1.18	0	0	< 10
9: DW DW-Elliots Construction (ACW)	06-Jan-25 13:50	8.8	1.47	0	0	30
10: RW RW3-Point Clark RW-Well 2	06-Jan-25 14:09	8.8	---	0	0	---
11: RW RW4-Point Clark RW-Well 3	06-Jan-25 14:14	8.8	---	0	0	---
12: TW TW3-Point Clark TW	06-Jan-25 14:04	8.8	1.41	0	0	< 10
13: DW DW-Point Clark Community Centre	06-Jan-25 14:30	8.8	1.49	0	0	< 10
14: RW RW5-Murdoch Glen RW-Well	06-Jan-25 15:44	8.8	---	0	0	---
15: TW TW4-Murdoch Glen TW	06-Jan-25 15:45	8.8	1.52	0	0	< 10
16: RW RW2-Huronville South RW-Well 1	06-Jan-25 15:25	8.8	---	0	0	---
17: TW TW2-Huronville South TW	06-Jan-25 15:21	8.8	1.56	0	0	< 10
18: DW DW-Inverlyn Club House	06-Jan-25 16:02	8.8	1.36	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Cristal Schuster
 Project Specialist-London,



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20301-JAN25

Environment, Health & Safety