

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

22-November-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

Date Rec. : 19 November 2024  
 LR Report: CA20896-NOV24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	20-Nov-24	20-Nov-24	20-Nov-24
2: Analysis Start Time		---	---	10:05	10:05	09:35
3: Analysis Completed Date		---	---	22-Nov-24	22-Nov-24	22-Nov-24
4: Analysis Completed Time		---	---	10:07	10:07	10:07
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	18-Nov-24 13:10	5.2	---	0	0	---
7: TW Huronville South Treated Water	18-Nov-24 13:10	5.2	1.55	0	0	< 10
8: RW Murdock Glen Raw Water	18-Nov-24 13:25	5.2	---	0	0	---
9: TW Murdock Glen Treated Water	18-Nov-24 13:25	5.2	1.63	0	0	< 10
10: RW Blairs Grove Raw Water	18-Nov-24 14:00	5.2	---	0	0	---
11: TW Blairs Grove Treated Water	18-Nov-24 14:00	5.2	1.43	0	0	< 10
12: RW Point Clark Raw Water #2	18-Nov-24 14:25	5.2	---	0	0	---
13: RW Point Clark Raw Water #3	18-Nov-24 14:25	5.2	---	0	0	---
14: TW Point Clark Treated Water	18-Nov-24 14:20	5.2	1.60	0	0	< 10
15: DW DW Amberley Beach	18-Nov-24 14:45	5.2	1.45	0	0	< 10
16: DW DW Chem Shed	18-Nov-24 13:55	5.2	1.31	0	0	< 10
17: DW DW Bruce Beach SS	18-Nov-24 13:40	5.2	1.43	0	0	---
18: DW DW Inverlyn CH	18-Nov-24 13:00	5.2	1.46	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Cristal Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20896-NOV24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

15-November-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

**Date Rec. :** 12 November 2024  
**LR Report:** CA20531-NOV24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

**Copy:** #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	13-Nov-24	13-Nov-24	13-Nov-24
2: Analysis Start Time		---	---	09:55	09:55	09:20
3: Analysis Completed Date		---	---	15-Nov-24	15-Nov-24	15-Nov-24
4: Analysis Completed Time		---	---	10:17	10:17	10:17
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	11-Nov-24 11:20	7.1	---	0	0	---
7: TW Huronville South Treated Water	11-Nov-24 11:25	7.1	1.50	0	0	30
8: RW Murdock Glen Raw Water	11-Nov-24 12:30	7.1	---	0	0	---
9: TW Murdock Glen Treated Water	11-Nov-24 12:25	7.1	1.58	0	0	< 10
10: RW Blairs Grove Raw Water	11-Nov-24 12:50	7.1	---	0	0	---
11: TW Blairs Grove Treated Water	11-Nov-24 12:50	7.1	1.50	0	0	< 10
12: RW Point Clark Raw Water #2	11-Nov-24 13:25	7.1	---	0	0	---
13: RW Point Clark Raw Water #3	11-Nov-24 13:25	7.1	---	0	0	---
14: TW Point Clark Treated Water	11-Nov-24 13:25	7.1	1.75	0	0	< 10
15: DW DW-Amberley Beach SS	11-Nov-24 13:50	7.1	1.74	0	0	< 10
16: DW DW-Bruce Beach SS	11-Nov-24 12:05	7.1	1.20	0	0	< 10
17: DW DW-Inverlyn CH	11-Nov-24 11:45	7.1	1.19	0	0	---
18: DW DW-Chem Shed	11-Nov-24 13:10	7.1	1.31	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**Cristal Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20531-NOV24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

08-November-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

**Date Rec. :** 05 November 2024  
**LR Report:** CA20240-NOV24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

**Copy:** #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	06-Nov-24	06-Nov-24	06-Nov-24
2: Analysis Start Time		---	---	10:15	10:15	09:40
3: Analysis Completed Date		---	---	08-Nov-24	08-Nov-24	08-Nov-24
4: Analysis Completed Time		---	---	10:10	10:10	10:10
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	04-Nov-24 13:40	10.8	---	0	0	---
7: TW Huronville South Treated Water	04-Nov-24 13:35	10.8	1.57	0	0	< 10
8: RW Murdock Glen Raw Water	04-Nov-24 13:10	10.8	---	0	0	---
9: TW Murdock Glen Treated Water	04-Nov-24 13:05	10.8	1.65	0	0	< 10
10: RW Blairs Grove Raw Water	04-Nov-24 12:30	10.8	---	0	0	---
11: TW Blairs Grove Treated Water	04-Nov-24 12:27	10.8	1.45	0	0	< 10
12: RW Point Clark Raw Water #2	04-Nov-24 11:50	10.8	---	0	0	---
13: RW Point Clark Raw Water #3	04-Nov-24 11:51	10.8	---	0	0	---
14: TW Point Clark Treated Water	04-Nov-24 11:53	10.8	1.77	0	0	< 10
15: DW DW - Amberley Beach SS	04-Nov-24 11:35	10.8	1.56	0	0	< 10
16: DW DW - Chem Shed	04-Nov-24 12:15	10.8	1.47	0	0	< 10
17: DW DW - Bruce Beach SS	04-Nov-24 12:50	10.8	1.52	0	0	---
18: DW DW - Inverlyn CH	04-Nov-24 13:50	10.8	1.57	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



**Cristal Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20240-NOV24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

01-November-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

Date Rec. : 29 October 2024  
 LR Report: CA21599-OCT24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	30-Oct-24	30-Oct-24	30-Oct-24
2: Analysis Start Time		---	---	10:15	10:15	09:35
3: Analysis Completed Date		---	---	01-Nov-24	01-Nov-24	01-Nov-24
4: Analysis Completed Time		---	---	09:39	09:39	09:39
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	28-Oct-24 15:16	10.6	---	0	0	---
7: TW Huronville South Treated Water	28-Oct-24 15:10	10.6	1.46	0	0	< 10
8: RW Murdock Glen Raw Water	28-Oct-24 14:45	10.6	---	0	0	---
9: TW Murdock Glen Treated Water	28-Oct-24 14:42	10.6	1.52	0	0	< 10
10: RW Blairs Grove Raw Water	28-Oct-24 14:17	10.6	---	0	0	---
11: TW Blairs Grove Treated Water	28-Oct-24 14:15	10.6	1.28	0	0	< 10
12: RW Point Clark Raw Water #2	28-Oct-24 11:46	10.6	---	0	0	---
13: RW Point Clark Raw Water #3	28-Oct-24 11:45	10.6	---	0	0	---
14: TW Point Clark Treated Water	28-Oct-24 11:40	10.6	1.64	0	0	< 10
15: DW DW - Amberley Beach SS	28-Oct-24 11:30	10.6	1.30	0	0	< 10
16: DW DW - Chem Shed	28-Oct-24 14:00	10.6	1.39	0	0	< 10
17: DW DW - Bruce Beach SS	28-Oct-24 14:35	10.6	1.45	0	0	---
18: DW DW - Inverlyn CH	28-Oct-24 15:25	10.6	1.29	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



**Cristal Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA21599-OCT24

*Environment, Health & Safety*



**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

25-October-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

Date Rec. : 22 October 2024  
 LR Report: CA21242-OCT24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	23-Oct-24	23-Oct-24	23-Oct-24
2: Analysis Start Time		---	---	11:25	11:25	10:10
3: Analysis Completed Date		---	---	25-Oct-24	25-Oct-24	25-Oct-24
4: Analysis Completed Time		---	---	11:25	11:25	11:25
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	21-Oct-24 15:12	10.4	---	0	0	---
7: TW Huronville South Treated Water	21-Oct-24 15:10	10.4	1.51	0	0	10
8: RW Murdock Glen Raw Water	21-Oct-24 14:50	10.4	---	0	0	---
9: TW Murdock Glen Treated Water	21-Oct-24 14:45	10.4	1.55	0	0	< 10
10: RW Blairs Grove Raw Water	21-Oct-24 13:55	10.4	---	0	0	---
11: TW Blairs Grove Treated Water	21-Oct-24 13:45	10.4	1.31	0	0	< 10
12: RW Point Clark Raw Water #2	21-Oct-24 12:42	10.4	---	0	0	---
13: RW Point Clark Raw Water #3	21-Oct-24 12:40	10.4	---	0	0	---
14: TW Point Clark Treated Water	21-Oct-24 12:25	10.4	1.54	0	0	< 10
15: DW DW Amberley Beach SS	21-Oct-24 12:52	10.4	1.39	0	0	< 10
16: DW DW Chem Shed	21-Oct-24 13:30	10.4	1.28	0	0	< 10
17: DW DW Bruce Beach SS	21-Oct-24 14:30	10.4	1.33	0	0	---
18: DW DW Inverlyn CH	21-Oct-24 15:20	10.4	1.33	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Cristal Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA21242-OCT24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

18-October-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

Date Rec. : 15 October 2024  
 LR Report: CA20800-OCT24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	16-Oct-24	16-Oct-24	16-Oct-24
2: Analysis Start Time		---	---	---	11:25	11:25	10:45
3: Analysis Completed Date		---	---	---	18-Oct-24	18-Oct-24	18-Oct-24
4: Analysis Completed Time		---	---	---	10:53	10:53	10:53
5: MAC		---	---	---	0	0	---
6: RW Huronville South Raw Water	15-Oct-24 11:45	13.1	---	0.17	0	0	---
7: TW Huronville South Treated Water	15-Oct-24 11:45	13.1	1.49	0.21	0	0	< 10
8: RW Murdock Glen Raw Water	15-Oct-24 11:25	13.1	---	0.25	0	0	---
9: TW Murdock Glen Treated Water	15-Oct-24 11:25	13.1	1.55	0.39	0	0	< 10
10: RW Blairs Grove Raw Water	15-Oct-24 10:05	13.1	---	0.41	0	0	---
11: TW Blairs Grove Treated Water	15-Oct-24 10:00	13.1	1.33	0.39	0	0	< 10
12: RW Point Clark Raw Water #2	15-Oct-24 09:30	13.1	---	0.23	0	0	---
13: RW Point Clark Raw Water #3	15-Oct-24 09:30	13.1	---	0.27	0	0	---
14: TW Point Clark Treated Water	15-Oct-24 09:30	13.1	1.58	0.33	0	0	< 10
15: DW Amberley SS	15-Oct-24 09:15	13.1	1.25	---	0	0	< 10
16: DW Chem Shed	15-Oct-24 09:50	13.1	1.26	---	0	0	< 10
17: DW Bruce Beach	15-Oct-24 11:15	13.1	1.50	---	0	0	---
18: DW Inverlyn CH	15-Oct-24 11:55	13.1	1.48	---	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Cristal Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20800-OCT24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

11-October-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

**Date Rec. :** 08 October 2024  
**LR Report:** CA20527-OCT24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

**Copy:** #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	09-Oct-24	09-Oct-24	09-Oct-24
2: Analysis Start Time		---	---	09:55	09:55	09:30
3: Analysis Completed Date		---	---	11-Oct-24	11-Oct-24	11-Oct-24
4: Analysis Completed Time		---	---	09:44	09:44	09:44
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	07-Oct-24 13:45	8.4	---	0	0	---
7: TW Huronville South Treated Water	07-Oct-24 13:50	8.4	1.44	0	0	< 10
8: RW Murdock Glen Raw Water	07-Oct-24 13:30	8.4	---	0	0	---
9: TW Murdock Glen Treated Water	07-Oct-24 13:25	8.4	1.49	0	0	< 10
10: RW Blairs Grove Raw Water	07-Oct-24 12:50	8.4	---	0	0	---
11: TW Blairs Grove Treated Water	07-Oct-24 12:50	8.4	1.33	0	0	< 10
12: RW Point Clark Raw Water #2	07-Oct-24 12:05	8.4	---	0	0	---
13: RW Point Clark Raw Water #3	07-Oct-24 12:05	8.4	---	0	0	---
14: TW Point Clark Treated Water	07-Oct-24 11:35	8.4	1.53	0	0	< 10
15: DW DW 86587 Amberley	07-Oct-24 11:15	8.4	1.28	0	0	< 10
16: DW DW Chem Shed	07-Oct-24 12:15	8.4	1.26	0	0	< 10
17: DW DW 138 Bruce Beach SS	07-Oct-24 13:10	8.4	1.44	0	0	---
18: DW DW Inverlyn CH	07-Oct-24 13:40	8.4	1.43	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



**Cristal Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20527-OCT24

*Environment, Health & Safety*



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

04-October-2024

Veolia Water (Lakeshore)

Attn : Steve Walmsley

Date Rec. : 01 October 2024
LR Report: CA20086-OCT24

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
Fax:519-524-9358

CERTIFICATE OF ANALYSIS
Final Report

Table with 7 columns: Sample ID, Sample Date & Time, Temperature Upon Receipt °C, Field ResCI Free mg/L, Total Coliform cfu/100mL, E.Coli cfu/100mL, Heterotrophic Plate Count (HPC) cfu/1mL. Rows include analysis dates, times, and 18 sample entries with their respective results.

MAC - Maximum Acceptable Concentration

Method Descriptions

Table with 4 columns: Units, Description, SGS Method Code, PALA. Rows describe E.Coli by MF, Heterotrophic Plate Count (HPC), and Total Coliform by MF.

Accreditation Descriptions

PALA:

SGS Canada Industries & Environment conforms to the requirements of ISO/IEC 17025: 2005 for specific tests as listed on their scope of accreditation found at https://www.ceaeq.gouv.qc.ca/documents/publications/listes.htm#labo\_accr. Analytes and SGS Method Codes marked with a "Y" in the "PALA" column in the table denote ISO/IEC17025: 2005 accreditation



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20086-OCT24

---

*Cristal Schuster  
Project Specialist-London,  
Environment, Health & Safety*



**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

27-September-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

Date Rec. : 24 September 2024  
 LR Report: CA21236-SEP24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	25-Sep-24	25-Sep-24	25-Sep-24
2: Analysis Start Time		---	---	10:05	10:05	09:30
3: Analysis Completed Date		---	---	27-Sep-24	27-Sep-24	27-Sep-24
4: Analysis Completed Time		---	---	11:29	11:29	11:29
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	23-Sep-24 13:10	10.2	---	0	0	---
7: TW Huronville South Treated Water	23-Sep-24 13:05	10.2	1.63	0	0	< 10
8: RW Murdock Glen Raw Water	23-Sep-24 13:20	10.2	---	0	0	---
9: TW Murdock Glen Treated Water	23-Sep-24 13:25	10.2	1.56	0	0	< 10
10: RW Blairs Grove Raw Water	23-Sep-24 14:15	10.2	---	0	0	---
11: TW Blairs Grove Treated Water	23-Sep-24 14:20	10.2	1.44	0	0	< 10
12: RW Point Clark Raw Water #2	23-Sep-24 14:50	10.2	---	0	0	---
13: RW Point Clark Raw Water #3	23-Sep-24 14:50	10.2	---	0	0	---
14: TW Point Clark Treated Water	23-Sep-24 14:40	10.2	1.49	0	0	< 10
15: DW 86591	23-Sep-24 15:00	10.2	1.43	0	0	< 10
16: DW Chem Shed	23-Sep-24 14:05	10.2	1.34	0	0	< 10
17: DW 138 Bruce Beach SS	23-Sep-24 13:51	10.2	1.50	0	0	---
18: DW Inverlyn CH	23-Sep-24 12:50	10.2	1.55	0	0	---

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.  
 Branch Manager-London  
 Environment, Health & Safety

**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA21236-SEP24

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

20-September-2024

**Veolia Water (Lakeshore)**

Attn : Chris Clarke

Date Rec. : 17 September 2024  
 LR Report: CA20920-SEP24

100 Cove Rd., Goderich  
 Canada, N7A 3Z2  
 Phone: 519-524-6583, Fax:519-524-9358

Copy: #1

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	18-Sep-24	18-Sep-24	18-Sep-24
2: Analysis Start Time		---	---	09:50	09:50	09:30
3: Analysis Completed Date		---	---	20-Sep-24	20-Sep-24	20-Sep-24
4: Analysis Completed Time		---	---	09:47	09:47	09:47
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	16-Sep-24 13:10	10.1	---	0	0	---
7: TW Huronville South Treated Water	16-Sep-24 13:15	10.1	1.52	0	0	< 10
8: RW Murdock Glen Raw Water	16-Sep-24 12:55	10.1	---	0	0	---
9: TW Murdock Glen Treated Water	16-Sep-24 12:50	10.1	1.59	0	0	< 10
10: RW Blairs Grove Raw Water	16-Sep-24 12:20	10.1	---	0	0	---
11: TW Blairs Grove Treated Water	16-Sep-24 12:20	10.1	1.40	0	0	>2000
12: RW Point Clark Raw Water #2	16-Sep-24 11:45	10.1	---	0	0	---
13: RW Point Clark Raw Water #3	16-Sep-24 11:45	10.1	---	0	0	---
14: TW Point Clark Treated Water	16-Sep-24 11:50	10.1	1.60	0	0	710
15: DW DW 86591 A. Beach	16-Sep-24 11:35	10.1	1.39	0	0	< 10
16: DW DW 138 B. Beach Rd	16-Sep-24 12:40	10.1	1.58	0	0	< 10
17: DW DW Inverlyn CH	16-Sep-24 13:30	10.1	1.43	0	0	---
18: DW DW Chem Shed	16-Sep-24 12:05	10.1	1.39	0	0	---

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.  
 Branch Manager-London  
 Environment, Health & Safety

**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20920-SEP24

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

13-September-2024

**Veolia Water (Lakeshore)**

Attn : Chris Clarke

Date Rec. : 10 September 2024  
 LR Report: CA20511-SEP24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	11-Sep-24	11-Sep-24	11-Sep-24
2: Analysis Start Time		---	---	10:05	10:05	09:20
3: Analysis Completed Date		---	---	13-Sep-24	13-Sep-24	13-Sep-24
4: Analysis Completed Time		---	---	10:58	10:58	10:58
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	09-Sep-24 12:42	9.0	---	0	0	---
7: TW Huronville South Treated Water	09-Sep-24 12:39	9.0	1.47	0	0	< 10
8: RW Murdock Glen Raw Water	09-Sep-24 12:12	9.0	---	0	0	---
9: TW Murdock Glen Treated Water	09-Sep-24 12:10	9.0	1.58	0	0	< 10
10: RW Blairs Grove Raw Water	09-Sep-24 11:41	9.0	---	0	0	---
11: TW Blairs Grove Treated Water	09-Sep-24 11:40	9.0	1.43	0	0	< 10
12: RW Point Clark Raw Water #2	09-Sep-24 11:12	9.0	---	0	0	---
13: RW Point Clark Raw Water #3	09-Sep-24 11:13	9.0	---	0	0	---
14: TW Point Clark Treated Water	09-Sep-24 11:10	9.0	1.76	0	0	< 10
15: DW DW-Amberley Beach SS	09-Sep-24 10:50	9.0	1.38	0	0	< 10
16: DW DW-Chem Shed	09-Sep-24 11:30	9.0	1.56	0	0	< 10
17: DW DW-Bruce Beach SS	09-Sep-24 12:00	9.0	1.48	0	0	---
18: DW DW-Inverlyn CH	09-Sep-24 13:10	9.0	1.34	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Works #: 220000425

**SGS Canada Inc.**

657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20511-SEP24

---

*Cristal Schuster  
Project Specialist-London,  
Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

06-September-2024

**Veolia Water (Lakeshore)**

Attn : Chris Clarke

**Date Rec. :** 03 September 2024  
**LR Report:** CA20087-SEP24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

**Copy:** #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	04-Sep-24	04-Sep-24	04-Sep-24
2: Analysis Start Time		---	---	11:10	11:10	10:45
3: Analysis Completed Date		---	---	06-Sep-24	06-Sep-24	06-Sep-24
4: Analysis Completed Time		---	---	10:59	10:59	10:59
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	03-Sep-24 13:44	17.0	---	0	0	---
7: TW Huronville South Treated Water	03-Sep-24 13:42	17.0	1.44	0	0	10
8: RW Murdock Glen Raw Water	03-Sep-24 13:06	17.0	---	0	0	---
9: TW Murdock Glen Treated Water	03-Sep-24 12:57	17.0	1.61	0	0	< 10
10: RW Blairs Grove Raw Water	03-Sep-24 12:18	17.0	---	0	0	---
11: TW Blairs Grove Treated Water	03-Sep-24 12:17	17.0	1.53	0	0	< 10
12: RW Point Clark Raw Water #2	03-Sep-24 11:10	17.0	---	0	0	---
13: RW Point Clark Raw Water #3	03-Sep-24 11:12	17.0	---	0	0	---
14: TW Point Clark Treated Water	03-Sep-24 11:20	17.0	1.75	0	0	10
15: DW DW 86591	03-Sep-24 11:03	17.0	1.30	0	0	< 10
16: DW DW Chem Shed	03-Sep-24 11:52	17.0	1.29	0	0	10
17: DW DW 138 Bruce Beach	03-Sep-24 12:46	17.0	1.50	0	0	---
18: DW DW Inverlyn CH	03-Sep-24 13:22	17.0	1.36	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



**Cristal Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20087-SEP24

*Environment, Health & Safety*



**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

30-August-2024

**Veolia Water (Lakeshore)**

Attn : Chris Clarke

Date Rec. : 27 August 2024  
 LR Report: CA21418-AUG24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL
1: Analysis Start Date		---	---	28-Aug-24	28-Aug-24
2: Analysis Start Time		---	---	09:40	09:40
3: Analysis Completed Date		---	---	30-Aug-24	30-Aug-24
4: Analysis Completed Time		---	---	10:34	10:34
5: MAC		---	---	0	0
6: NR East End #1	27-Aug-24 10:35	12.1	2.10	0	0
7: NR East End #2	27-Aug-24 11:10	12.1	2.15	0	0
8: NR Sample Relief #1	27-Aug-24 10:40	12.1	2.20	0	0
9: NR Sample Relief #2	27-Aug-24 11:15	12.1	2.20	0	0
10: NR Sample Spot 3 #1	27-Aug-24 10:45	12.1	2.14	0	0
11: NR Sample Spot 3 #2	27-Aug-24 11:20	12.1	2.18	0	0
12: NR Sample Spot 4 #1	27-Aug-24 10:50	12.1	2.20	0	0
13: NR Sample Spot 4 #2	27-Aug-24 11:25	12.1	2.20	0	0
14: NR Sample Spot 5 #1	27-Aug-24 10:55	12.1	2.20	0	0
15: NR Sample Spot 5 #2	27-Aug-24 11:30	12.1	2.20	0	0
16: NR Sample Spot 6 #1	27-Aug-24 11:00	12.1	2.20	0	0
17: NR Sample Spot 6 #2	27-Aug-24 11:35	12.1	2.20	0	0

MAC - Maximum Acceptable Concentration

NR - Not reportable under applicable Provincial drinking water regulations as per client.

#### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**Angela Stott, B.Sc.**  
 Branch Manager-London  
 Environment, Health & Safety

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

30-August-2024

**Veolia Water (Lakeshore)**

Attn : Chris Clarke

Date Rec. : 27 August 2024  
 LR Report: CA21419-AUG24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	28-Aug-24	28-Aug-24	28-Aug-24
2: Analysis Start Time		---	---	09:40	09:40	09:15
3: Analysis Completed Date		---	---	30-Aug-24	30-Aug-24	30-Aug-24
4: Analysis Completed Time		---	---	10:34	10:34	10:34
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	26-Aug-24 12:49	13.4	---	0	0	---
7: TW Huronville South Treated Water	26-Aug-24 12:53	13.4	1.55	0	0	< 10
8: RW Murdock Glen Raw Water	26-Aug-24 13:30	13.4	---	0	0	---
9: TW Murdock Glen Treated Water	26-Aug-24 13:14	13.4	1.67	0	0	< 10
10: RW Blairs Grove Raw Water	26-Aug-24 13:56	13.4	---	0	0	---
11: TW Blairs Grove Treated Water	26-Aug-24 13:54	13.4	1.53	0	0	< 10
12: RW Point Clark Raw Water #2	26-Aug-24 14:33	13.4	---	0	0	---
13: RW Point Clark Raw Water #3	26-Aug-24 14:30	13.4	---	0	0	---
14: TW Point Clark Treated Water	26-Aug-24 14:23	13.4	1.66	0	0	< 10
15: DW DW Amberley Beach SS	26-Aug-24 14:55	13.4	1.45	0	0	< 10
16: DW DW Inverlyn Clubhouse	26-Aug-24 12:39	13.4	1.13	0	0	< 10
17: DW DW Chem Shed	26-Aug-24 13:45	13.4	1.54	0	0	---
18: DW DW Bruce Beach Rd	26-Aug-24 13:14	13.4	1.45	0	0	---

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.  
 Branch Manager-London  
 Environment, Health & Safety

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

23-August-2024

**Veolia Water (Lakeshore)**

Attn : Chris Clarke

Date Rec. : 20 August 2024  
 LR Report: CA21033-AUG24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	21-Aug-24	21-Aug-24	21-Aug-24
2: Analysis Start Time		---	---	09:30	09:30	09:05
3: Analysis Completed Date		---	---	23-Aug-24	23-Aug-24	23-Aug-24
4: Analysis Completed Time		---	---	09:49	09:49	09:49
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	19-Aug-24 12:10	5.4	---	0	0	---
7: TW Huronville South Treated Water	19-Aug-24 12:13	5.4	1.51	0	0	< 10
8: RW Murdock Glen Raw Water	19-Aug-24 12:35	5.4	---	0	0	---
9: TW Murdock Glen Treated Water	19-Aug-24 12:37	5.4	1.65	0	0	10
10: RW Blairs Grove Raw Water	19-Aug-24 13:23	5.4	---	0	0	---
11: TW Blairs Grove Treated Water	19-Aug-24 13:18	5.4	1.45	0	0	< 10
12: RW Point Clark Raw Water #2	19-Aug-24 13:36	5.4	---	0	0	---
13: RW Point Clark Raw Water #3	19-Aug-24 13:39	5.4	---	0	0	---
14: TW Point Clark Treated Water	19-Aug-24 13:42	5.4	1.54	0	0	< 10
15: DW DW Inverfyn Clubhouse	19-Aug-24 11:55	5.4	1.43	0	0	< 10
16: DW DW Amberly Beach	19-Aug-24 14:00	5.4	1.41	0	0	< 10
17: DW DW 139 Bruce Beach Rd.	19-Aug-24 12:56	5.4	1.43	0	0	---
18: DW DW Chem Shed	19-Aug-24 13:09	5.4	1.42	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code	PALA
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001	N
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002	N
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001	N

### Accreditation Descriptions

**PALA:**

SGS Canada Industries & Environment conforms to the requirements of ISO/IEC 17025: 2005 for specific tests as listed on their scope of accreditation found at [https://www.ceaegouv.qc.ca/documents/publications/lites.htm#labo\\_accr](https://www.ceaegouv.qc.ca/documents/publications/lites.htm#labo_accr). Analytes and SGS Method Codes marked with a "Y" in the "PALA" column in the table denote ISO/IEC17025: 2005 accreditation



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA21033-AUG24

---

*Cristal Schuster  
Project Specialist-London,  
Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

16-August-2024

**Veolia Water (Lakeshore)**

Attn : Chris Clarke

Date Rec. : 13 August 2024  
 LR Report: CA20642-AUG24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	14-Aug-24	14-Aug-24	14-Aug-24
2: Analysis Start Time		---	---	10:00	10:00	09:20
3: Analysis Completed Date		---	---	16-Aug-24	16-Aug-24	16-Aug-24
4: Analysis Completed Time		---	---	11:23	11:23	11:23
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	12-Aug-24 11:30	7.1	---	0	0	---
7: TW Huronville South Treated Water	12-Aug-24 11:30	7.1	1.47	0	0	70
8: RW Murdock Glen Raw Water	12-Aug-24 12:10	7.1	---	0	0	---
9: TW Murdock Glen Treated Water	12-Aug-24 12:10	7.1	1.56	0	0	< 10
10: RW Blairs Grove Raw Water	12-Aug-24 12:40	7.1	---	0	0	---
11: TW Blairs Grove Treated Water	12-Aug-24 12:40	7.1	1.50	0	0	< 10
12: RW Point Clark Raw Water #2	12-Aug-24 13:35	7.1	---	0	0	---
13: RW Point Clark Raw Water #3	12-Aug-24 13:35	7.1	---	0	0	---
14: TW Point Clark Treated Water	12-Aug-24 13:25	7.1	1.64	0	0	< 10
15: DW DW Amberley Beach SS	12-Aug-24 14:00	7.1	1.54	0	0	< 10
16: DW DW Inverlyn CH	12-Aug-24 11:45	7.1	1.23	0	0	< 10
17: DW DW Tanglewood SS	12-Aug-24 12:00	7.1	1.45	0	0	---
18: DW DW Chem Shed	12-Aug-24 13:00	7.1	1.39	0	0	---

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.  
 Branch Manager-London  
 Environment, Health & Safety



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

09-August-2024

**Veolia Water (Lakeshore)**

Attn : Chris Clarke

Date Rec. : 06 August 2024  
 LR Report: CA20164-AUG24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	07-Aug-24	07-Aug-24	07-Aug-24
2: Analysis Start Time		---	---	13:20	13:20	12:35
3: Analysis Completed Date		---	---	09-Aug-24	09-Aug-24	09-Aug-24
4: Analysis Completed Time		---	---	12:17	12:17	12:17
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	06-Aug-24 11:30	12.4	---	0	0	---
7: TW Huronville South Treated Water	06-Aug-24 11:30	12.4	1.49	0	0	10
8: RW Murdock Glen Raw Water	06-Aug-24 11:05	12.4	---	0	0	---
9: TW Murdock Glen Treated Water	06-Aug-24 11:05	12.4	1.61	0	0	10
10: RW Blairs Grove Raw Water	06-Aug-24 10:40	12.4	---	0	0	---
11: TW Blairs Grove Treated Water	06-Aug-24 10:35	12.4	1.45	0	0	< 10
12: RW Point Clark Raw Water #2	06-Aug-24 10:15	12.4	---	0	0	---
13: RW Point Clark Raw Water #3	06-Aug-24 10:15	12.4	---	0	0	---
14: TW Point Clark Treated Water	06-Aug-24 10:10	12.4	1.77	0	0	< 10
15: DW DW Amberley SS	06-Aug-24 10:00	12.4	1.38	0	0	< 10
16: DW DW Chem Shed	06-Aug-24 10:30	12.4	1.32	0	0	< 10
17: DW DW Bruce Beach	06-Aug-24 10:55	12.4	1.44	0	0	---
18: DW DW Inverlyn CH	06-Aug-24 11:25	12.4	1.21	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



**Cristal Schuster**  
 Project Specialist-London,





**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20164-AUG24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

02-August-2024

**Veolia Water (Lakeshore)**

Attn : Chris Clarke

Date Rec. : 30 July 2024  
 LR Report: CA21627-JUL24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	31-Jul-24	31-Jul-24	31-Jul-24
2: Analysis Start Time		---	---	09:20	09:20	09:00
3: Analysis Completed Date		---	---	02-Aug-24	02-Aug-24	02-Aug-24
4: Analysis Completed Time		---	---	09:59	09:59	09:59
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	29-Jul-24 13:25	6.4	---	0	0	---
7: TW Huronville South Treated Water	29-Jul-24 13:27	6.4	1.49	0	0	< 10
8: RW Murdock Glen Raw Water	29-Jul-24 13:10	6.4	---	0	0	---
9: TW Murdock Glen Treated Water	29-Jul-24 13:12	6.4	1.55	0	0	< 10
10: RW Blairs Grove Raw Water	29-Jul-24 12:35	6.4	---	0	0	---
11: TW Blairs Grove Treated Water	29-Jul-24 12:30	6.4	1.40	0	0	< 10
12: RW Point Clark Raw Water #2	29-Jul-24 11:45	6.4	---	0	0	---
13: RW Point Clark Raw Water #3	29-Jul-24 11:47	6.4	---	0	0	---
14: TW Point Clark Treated Water	29-Jul-24 11:50	6.4	1.59	0	0	< 10
15: DW DW Amberley Beach SS	29-Jul-24 11:35	6.4	1.57	0	0	< 10
16: DW DW Chem Shed	29-Jul-24 12:15	6.4	1.42	0	0	< 10
17: DW DW Bruce Beach SS	29-Jul-24 12:55	6.4	1.49	0	0	---
18: DW DW Inverlyn CH	29-Jul-24 13:50	6.4	1.41	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



**Cristal Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA21627-JUL24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

26-July-2024

**Veolia Water (Lakeshore)**  
 Attn : Steve Walmsley

**Date Rec. :** 23 July 2024  
**LR Report:** CA21300-JUL24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

**Copy:** #1

Phone: 519-524-6583  
 Fax:519-524-9358

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	24-Jul-24	24-Jul-24	24-Jul-24
2: Analysis Start Time		---	---	09:50	09:50	09:15
3: Analysis Completed Date		---	---	26-Jul-24	26-Jul-24	26-Jul-24
4: Analysis Completed Time		---	---	10:24	10:24	10:24
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	22-Jul-24 14:30	8.0	---	0	0	---
7: TW Huronville South Treated Water	22-Jul-24 14:25	8.0	1.59	0	0	< 10
8: RW Murdock Glen Raw Water	22-Jul-24 14:10	8.0	---	0	0	---
9: TW Murdock Glen Treated Water	22-Jul-24 14:03	8.0	1.63	0	0	10
10: RW Blairs Grove Raw Water	22-Jul-24 13:35	8.0	---	0	0	---
11: TW Blairs Grove Treated Water	22-Jul-24 13:32	8.0	1.45	0	0	< 10
12: RW Point Clark Raw Water #2	22-Jul-24 12:30	8.0	---	0	0	---
13: RW Point Clark Raw Water #3	22-Jul-24 12:32	8.0	---	0	0	---
14: TW Point Clark Treated Water	22-Jul-24 12:15	8.0	1.63	0	0	< 10
15: DW DW - Amberley Beach SS	22-Jul-24 11:50	8.0	1.48	0	0	< 10
16: DW DW - Chem. Shed	22-Jul-24 12:45	8.0	1.41	0	0	< 10
17: DW DW - Bruce Beach SS	22-Jul-24 13:50	8.0	1.50	0	0	---
18: DW DW - Inverlyn CH	22-Jul-24 14:45	8.0	1.42	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



**Cristal Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA21300-JUL24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

22-July-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

Date Rec. : 16 July 2024  
 LR Report: CA20930-JUL24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	17-Jul-24	17-Jul-24	17-Jul-24
2: Analysis Start Time		---	---	09:20	09:20	09:00
3: Analysis Completed Date		---	---	19-Jul-24	19-Jul-24	19-Jul-24
4: Analysis Completed Time		---	---	12:33	12:33	12:33
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	15-Jul-24 14:16	9.1	---	0	0	---
7: TW Huronville South Treated Water	15-Jul-24 14:10	9.1	1.58	0	0	< 10
8: RW Murdock Glen Raw Water	15-Jul-24 14:44	9.1	---	0	0	---
9: TW Murdock Glen Treated Water	15-Jul-24 14:38	9.1	1.57	0	0	40
10: RW Blairs Grove Raw Water	15-Jul-24 13:35	9.1	---	0	0	---
11: TW Blairs Grove Treated Water	15-Jul-24 13:40	9.1	1.30	0	0	10
12: RW Point Clark Raw Water #2	15-Jul-24 14:10	9.1	---	0	0	---
13: RW Point Clark Raw Water #3	15-Jul-24 14:10	9.1	---	0	0	---
14: TW Point Clark Treated Water	15-Jul-24 14:15	9.1	1.57	0	0	< 10
15: DW DW Amberley Beach S5	15-Jul-24 15:35	9.1	1.49	0	0	< 10
16: DW DW Inverlyn CH	15-Jul-24 13:50	9.1	1.50	0	0	< 10
17: DW DW Chem Shed	15-Jul-24 15:15	9.1	1.44	0	0	---
18: DW DW Bruce Beach SS	15-Jul-24 14:57	9.1	1.45	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Crista Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20930-JUL24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

12-July-2024

**Veolia Water (Lakeshore)**  
 Attn : Steve Walmsley

Date Rec. : 09 July 2024  
 LR Report: CA20544-JUL24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	10-Jul-24	10-Jul-24	10-Jul-24
2: Analysis Start Time		---	---	09:20	09:20	09:05
3: Analysis Completed Date		---	---	12-Jul-24	12-Jul-24	12-Jul-24
4: Analysis Completed Time		---	---	10:14	10:14	10:14
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	08-Jul-24 10:35	11.9	---	0	0	---
7: TW Huronville South Treated Water	08-Jul-24 10:30	11.9	1.60	0	0	< 10
8: RW Murdock Glen Raw Water	08-Jul-24 11:05	11.9	---	0	0	---
9: TW Murdock Glen Treated Water	08-Jul-24 11:05	11.9	1.66	0	0	< 10
10: RW Blairs Grove Raw Water	08-Jul-24 11:45	11.9	---	0	0	---
11: TW Blairs Grove Treated Water	08-Jul-24 11:45	11.9	1.45	0	0	< 10
12: RW Point Clark Raw Water #2	08-Jul-24 13:05	11.9	---	0	0	---
13: RW Point Clark Raw Water #3	08-Jul-24 13:05	11.9	---	0	0	---
14: TW Point Clark Treated Water	08-Jul-24 13:05	11.9	1.58	0	0	10
15: DW DW Amberley Beach	08-Jul-24 13:25	11.9	1.56	0	0	< 10
16: DW DW Inverlyn CH	08-Jul-24 10:50	11.9	1.48	0	0	< 10
17: DW DW Bruce Beach	08-Jul-24 11:20	11.9	1.56	0	0	---
18: DW DW Chem Shed	08-Jul-24 11:35	11.9	1.37	0	0	---

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.  
 Branch Manager-London  
 Environment, Health & Safety



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20544-JUL24

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

05-July-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

Date Rec. : 02 July 2024  
 LR Report: CA20077-JUL24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	03-Jul-24	03-Jul-24	03-Jul-24
2: Analysis Start Time		---	---	13:40	13:40	13:05
3: Analysis Completed Date		---	---	05-Jul-24	05-Jul-24	05-Jul-24
4: Analysis Completed Time		---	---	11:46	11:46	11:46
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	02-Jul-24 09:10	14.6	---	0	0	---
7: TW Huronville South Treated Water	02-Jul-24 09:05	14.6	1.59	0	0	< 10
8: RW Murdock Glen Raw Water	02-Jul-24 09:20	14.6	---	0	0	---
9: TW Murdock Glen Treated Water	02-Jul-24 09:20	14.6	1.50	0	0	< 10
10: RW Blairs Grove Raw Water	02-Jul-24 09:50	14.6	---	0	0	---
11: TW Blairs Grove Treated Water	02-Jul-24 09:50	14.6	1.41	0	0	< 10
12: RW Point Clark Raw Water #2	02-Jul-24 10:20	14.6	---	0	0	---
13: RW Point Clark Raw Water #3	02-Jul-24 10:20	14.6	---	0	0	---
14: TW Point Clark Treated Water	02-Jul-24 10:20	14.6	1.52	0	0	< 10
15: DW DW Inverlyn CH	02-Jul-24 08:50	14.6	1.37	0	0	< 10
16: DW DW Amberley Beach	02-Jul-24 10:45	14.6	1.45	0	0	< 10
17: DW DW Bruce Beach	02-Jul-24 09:35	14.6	1.51	0	0	---
18: DW DW Chem Shed	02-Jul-24 10:10	14.6	1.39	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Cristal Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20077-JUL24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

28-June-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

Date Rec. : 25 June 2024  
 LR Report: CA21408-JUN24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	26-Jun-24	26-Jun-24	26-Jun-24
2: Analysis Start Time		---	---	09:55	09:55	09:25
3: Analysis Completed Date		---	---	28-Jun-24	28-Jun-24	28-Jun-24
4: Analysis Completed Time		---	---	10:07	10:07	10:07
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	24-Jun-24 14:38	9.0	---	0	0	---
7: TW Huronville South Treated Water	24-Jun-24 14:35	9.0	1.43	0	0	< 10
8: RW Murdock Glen Raw Water	24-Jun-24 14:10	9.0	---	0	0	---
9: TW Murdock Glen Treated Water	24-Jun-24 14:08	9.0	1.54	0	0	< 10
10: RW Blairs Grove Raw Water	24-Jun-24 13:15	9.0	---	0	0	---
11: TW Blairs Grove Treated Water	24-Jun-24 13:10	9.0	1.43	0	0	< 10
12: RW Point Clark Raw Water #2	24-Jun-24 12:30	9.0	---	0	0	---
13: RW Point Clark Raw Water #3	24-Jun-24 12:33	9.0	---	0	0	---
14: TW Point Clark Treated Water	24-Jun-24 12:36	9.0	1.65	0	0	< 10
15: DW DW - Amberley Beach SS	24-Jun-24 12:00	9.0	1.58	0	0	< 10
16: DW DW - Inverlyn CH	24-Jun-24 14:50	9.0	1.38	0	0	< 10
17: DW DW - Chem Shed	24-Jun-24 13:25	9.0	1.43	0	0	---
18: DW DW - Bruce Beach SS	24-Jun-24 13:55	9.0	1.47	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



**Cristal Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA21408-JUN24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

21-June-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

Date Rec. : 18 June 2024  
 LR Report: CA20983-JUN24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	19-Jun-24	19-Jun-24	19-Jun-24
2: Analysis Start Time		---	---	09:40	09:40	09:15
3: Analysis Completed Date		---	---	21-Jun-24	21-Jun-24	21-Jun-24
4: Analysis Completed Time		---	---	09:46	09:46	09:46
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	17-Jun-24 11:10	15.5	---	0	0	---
7: TW Huronville South Treated Water	17-Jun-24 11:10	15.5	1.45	0	0	< 10
8: RW Murdock Glen Raw Water	17-Jun-24 11:35	15.5	---	0	0	---
9: TW Murdock Glen Treated Water	17-Jun-24 11:35	15.5	1.50	0	0	10
10: RW Blairs Grove Raw Water	17-Jun-24 12:20	15.5	---	0	0	---
11: TW Blairs Grove Treated Water	17-Jun-24 12:20	15.5	1.44	0	0	10
12: RW Point Clark Raw Water #2	17-Jun-24 12:55	15.5	---	0	0	---
13: RW Point Clark Raw Water #3	17-Jun-24 12:55	15.5	---	0	0	---
14: TW Point Clark Treated Water	17-Jun-24 12:50	15.5	1.60	0	0	< 10
15: DW DW Amberley Beach	17-Jun-24 13:10	15.5	1.53	0	0	< 10
16: DW DW Chem Shed	17-Jun-24 12:40	15.5	1.36	0	0	< 10
17: DW DW Bruce Beach	17-Jun-24 12:05	15.5	1.43	0	0	---
18: DW DW Inverlyn CH	17-Jun-24 11:00	15.5	1.26	0	0	---

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.  
 Branch Manager-London  
 Environment, Health & Safety

**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20983-JUN24

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

14-June-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

Date Rec. : 11 June 2024  
 LR Report: CA20581-JUN24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	12-Jun-24	12-Jun-24	12-Jun-24
2: Analysis Start Time		---	---	10:10	10:10	09:30
3: Analysis Completed Date		---	---	14-Jun-24	14-Jun-24	14-Jun-24
4: Analysis Completed Time		---	---	09:37	09:37	09:37
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	10-Jun-24 12:45	7.8	---	0	0	---
7: TW Huronville South Treated Water	10-Jun-24 12:40	7.8	1.38	0	0	< 10
8: RW Murdock Glen Raw Water	10-Jun-24 13:10	7.8	---	0	0	---
9: TW Murdock Glen Treated Water	10-Jun-24 13:10	7.8	1.61	0	0	< 10
10: RW Blairs Grove Raw Water	10-Jun-24 13:25	7.8	---	0	0	---
11: TW Blairs Grove Treated Water	10-Jun-24 13:25	7.8	1.44	0	0	< 10
12: RW Point Clark Raw Water #2	10-Jun-24 13:55	7.8	---	0	0	---
13: RW Point Clark Raw Water #3	10-Jun-24 13:55	7.8	---	0	0	---
14: TW Point Clark Treated Water	10-Jun-24 13:50	7.8	1.32	0	0	< 10
15: DW DW - Amberley Beach SS	10-Jun-24 14:25	7.8	1.37	0	0	< 10
16: DW DW Bruce Beach SS	10-Jun-24 10:30	7.8	1.46	0	0	< 10
17: DW DW Inverlyn CH	10-Jun-24 12:50	7.8	1.18	0	0	---
18: DW DW Pt Clark Ball	10-Jun-24 13:40	7.8	0.99	0	0	---

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.  
 Branch Manager-London  
 Environment, Health & Safety



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20581-JUN24

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

07-June-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

Date Rec. : 04 June 2024  
 LR Report: CA20199-JUN24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	05-Jun-24	05-Jun-24	05-Jun-24
2: Analysis Start Time		---	---	09:45	09:45	09:20
3: Analysis Completed Date		---	---	07-Jun-24	07-Jun-24	07-Jun-24
4: Analysis Completed Time		---	---	09:54	09:54	09:54
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	03-Jun-24 11:45	8.6	---	0	0	---
7: TW Huronville South Treated Water	03-Jun-24 11:45	8.6	1.50	0	0	< 10
8: RW Murdock Glen Raw Water	03-Jun-24 12:00	8.6	---	0	0	---
9: TW Murdock Glen Treated Water	03-Jun-24 12:00	8.6	1.54	0	0	< 10
10: RW Blairs Grove Raw Water	03-Jun-24 12:20	8.6	---	0	0	---
11: TW Blairs Grove Treated Water	03-Jun-24 12:20	8.6	1.13	0	0	< 10
12: RW Point Clark Raw Water #2	03-Jun-24 13:00	8.6	---	0	0	---
13: RW Point Clark Raw Water #3	03-Jun-24 13:00	8.6	---	0	0	---
14: TW Point Clark Treated Water	03-Jun-24 12:50	8.6	1.35	0	0	< 10
15: DW DW Inverlyn CH	03-Jun-24 11:25	8.6	1.21	0	0	< 10
16: DW DW Pt Clark Comm	03-Jun-24 12:30	8.6	1.21	0	0	< 10
17: DW DW Tanglewood SS	03-Jun-24 13:10	8.6	1.36	0	0	---
18: DW DW Amberley SS	03-Jun-24 13:15	8.6	1.21	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



**Cristal Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20199-JUN24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

31-May-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

Date Rec. : 28 May 2024  
 LR Report: CA21472-MAY24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	29-May-24	29-May-24	29-May-24
2: Analysis Start Time		---	---	09:55	09:55	09:20
3: Analysis Completed Date		---	---	31-May-24	31-May-24	31-May-24
4: Analysis Completed Time		---	---	11:25	11:25	11:25
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	27-May-24 13:55	12.1	---	0	0	---
7: TW Huronville South Treated Water	27-May-24 13:52	12.1	1.59	0	0	< 10
8: RW Murdock Glen Raw Water	27-May-24 14:30	12.1	---	0	0	---
9: TW Murdock Glen Treated Water	27-May-24 14:25	12.1	1.66	0	0	< 10
10: RW Blairs Grove Raw Water	27-May-24 15:00	12.1	---	0	0	---
11: TW Blairs Grove Treated Water	27-May-24 14:55	12.1	1.39	0	0	< 10
12: RW Point Clark Raw Water #2	27-May-24 15:30	12.1	---	0	0	---
13: RW Point Clark Raw Water #3	27-May-24 15:35	12.1	---	0	0	---
14: TW Point Clark Treated Water	27-May-24 15:25	12.1	1.76	0	0	< 10
15: DW DW - Amberley Beach SS	27-May-24 15:45	12.1	1.66	0	0	< 10
16: DW DW PC Community Centre	27-May-24 15:10	12.1	1.35	0	0	< 10
17: DW DW Bruce Beach SS	27-May-24 14:45	12.1	1.51	0	0	---
18: DW DW Inverlyn CH	27-May-24 13:40	12.1	1.41	0	0	---

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.  
 Branch Manager-London  
 Environment, Health & Safety

**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA21472-MAY24

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

24-May-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

Date Rec. : 21 May 2024  
 LR Report: CA21058-MAY24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	22-May-24	22-May-24	22-May-24
2: Analysis Start Time		---	---	15:00	15:00	14:10
3: Analysis Completed Date		---	---	24-May-24	24-May-24	24-May-24
4: Analysis Completed Time		---	---	12:53	12:53	12:53
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	21-May-24 11:00	12.9	---	0	0	---
7: TW Huronville South Treated Water	21 May-24 11:00	12.9	1.60	0	0	< 10
8: RW Murdock Glen Raw Water	21-May-24 10:45	12.9	---	0	0	---
9: TW Murdock Glen Treated Water	21-May-24 10:45	12.9	1.56	0	0	< 10
10: RW Blairs Grove Raw Water	21-May-24 10:10	12.9	---	0	0	---
11: TW Blairs Grove Treated Water	21-May-24 10:10	12.9	1.30	0	0	< 10
12: RW Point Clark Raw Water #2	21-May-24 09:35	12.9	---	0	0	---
13: RW Point Clark Raw Water #3	21-May-24 09:35	12.9	---	0	0	---
14: TW Point Clark Treated Water	21-May-24 09:35	12.9	1.67	0	0	< 10
15: DW DW - Amberley Beach SS	21-May-24 09:20	12.9	1.66	0	0	< 10
16: DW DW Comm Center	21-May-24 09:50	12.9	1.15	0	0	< 10
17: DW DW Bruce Beach	21-May-24 10:30	12.9	1.29	0	0	---
18: DW DW Amberley Shore	21-May-24 12:10	12.9	1.51	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



**Cristal Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA21058-MAY24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

17-May-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

Date Rec. : 14 May 2024  
 LR Report: CA20747-MAY24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	15-May-24	15-May-24	15-May-24
2: Analysis Start Time		---	---	09:50	09:50	09:15
3: Analysis Completed Date		---	---	17-May-24	17-May-24	17-May-24
4: Analysis Completed Time		---	---	12:58	12:58	12:58
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	13-May-24 14:21	9.1	---	0	0	---
7: TW Huronville South Treated Water	13-May-24 14:17	9.1	1.63	0	0	< 10
8: RW Murdock Glen Raw Water	13-May-24 14:00	9.1	---	0	0	---
9: TW Murdock Glen Treated Water	13-May-24 13:55	9.1	1.52	0	0	< 10
10: RW Blairs Grove Raw Water	13-May-24 13:10	9.1	---	0	0	---
11: TW Blairs Grove Treated Water	13-May-24 13:05	9.1	1.36	0	0	< 10
12: RW Point Clark Raw Water #2	13-May-24 12:35	9.1	---	0	0	---
13: RW Point Clark Raw Water #3	13-May-24 12:32	9.1	---	0	0	---
14: TW Point Clark Treated Water	13-May-24 12:30	9.1	1.56	0	0	< 10
15: DW DW - Amberley Beach SS	13-May-24 11:50	9.1	1.39	0	0	10
16: DW DW Inverlyn CH	13-May-24 14:30	9.1	1.59	0	0	< 10
17: DW DW Chem Shed	13-May-24 13:18	9.1	1.15	0	0	---
18: DW DW Bruce Beach SS	13-May-24 13:40	9.1	1.42	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



**Crista Schuster**  
 Project Specialist-London,





**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20747-MAY24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

10-May-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

Date Rec. : 07 May 2024  
 LR Report: CA20366-MAY24

100 Cove Rd., Goderich  
 Canada, N7A 3Z2  
 Phone: 519-524-6583, Fax:519-524-9358

Copy: #1

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	08-May-24	08-May-24	08-May-24
2: Analysis Start Time		---	---	09:40	09:40	09:25
3: Analysis Completed Date		---	---	10-May-24	10-May-24	10-May-24
4: Analysis Completed Time		---	---	09:50	09:50	09:50
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	06-May-24 11:30	11.3	---	0	0	---
7: TW Huronville South Treated Water	06-May-24 11:30	11.3	1.59	0	0	< 10
8: RW Murdock Glen Raw Water	06-May-24 11:55	11.3	---	0	0	---
9: TW Murdock Glen Treated Water	06-May-24 11:55	11.3	1.58	0	0	< 10
10: RW Blairs Grove Raw Water	06-May-24 12:45	11.3	---	0	0	---
11: TW Blairs Grove Treated Water	06-May-24 12:40	11.3	1.32	0	0	< 10
12: RW Point Clark Raw Water #2	06-May-24 11:35	11.3	---	0	0	---
13: RW Point Clark Raw Water #3	06-May-24 11:35	11.3	---	0	0	---
14: TW Point Clark Treated Water	06-May-24 11:30	11.3	1.62	0	0	< 10
15: DW DW - Amberley Beach SS	06-May-24 13:50	11.3	1.58	0	0	< 10
16: DW DW Inverlyn	06-May-24 11:15	11.3	1.56	0	0	< 10
17: DW DW Bruce Beach	06-May-24 12:05	11.3	1.48	0	0	---
18: DW DW Chem Shed	06-May-24 13:05	11.3	1.33	0	0	---

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.  
 Branch Manager-London  
 Environment, Health & Safety

**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20366-MAY24

### Method Descriptions

Units	Description	SGS Method Code	Reference Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001	OMOE MICROMFDC-E3407A
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002	SM 9215C
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001	OMOE MICROMFDC-E3407A

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

03-May-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

Date Rec. : 30 April 2024  
 LR Report: CA20017-MAY24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	01-May-24	01-May-24	01-May-24
2: Analysis Start Time		---	---	16:40	16:40	15:50
3: Analysis Completed Date		---	---	03-May-24	03-May-24	03-May-24
4: Analysis Completed Time		---	---	13:58	13:58	13:58
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	30-Apr-24 11:05	10.7	---	0	0	---
7: TW Huronville South Treated Water	30-Apr-24 11:00	10.7	1.60	0	0	< 10
8: RW Murdock Glen Raw Water	30-Apr-24 10:45	10.7	---	0	0	---
9: TW Murdock Glen Treated Water	30-Apr-24 10:45	10.7	1.50	0	0	< 10
10: RW Blairs Grove Raw Water	30-Apr-24 10:00	10.7	---	0	0	---
11: TW Blairs Grove Treated Water	30-Apr-24 09:55	10.7	1.28	0	0	< 10
12: RW Point Clark Raw Water #2	30-Apr-24 09:30	10.7	---	0	0	---
13: RW Point Clark Raw Water #3	30-Apr-24 09:30	10.7	---	0	0	---
14: TW Point Clark Treated Water	30-Apr-24 09:30	10.7	1.68	0	0	< 10
15: DW DW - Amberley Beach SS	30-Apr-24 09:20	10.7	1.47	0	0	< 10
16: DW DW Chem Shed	30-Apr-24 10:25	10.7	1.23	0	0	< 10
17: DW DW Bruce Beach	30-Apr-24 10:35	10.7	1.46	0	0	---
18: DW DW Inverlyn CH	30-Apr-24 11:15	10.7	1.47	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



**Cristal Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20017-MAY24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

26-April-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

Date Rec. : 23 April 2024  
 LR Report: CA21231-APR24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	24-Apr-24	24-Apr-24	24-Apr-24
2: Analysis Start Time		---	---	10:15	10:15	09:45
3: Analysis Completed Date		---	---	26-Apr-24	26-Apr-24	26-Apr-24
4: Analysis Completed Time		---	---	10:01	10:01	10:01
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	22-Apr-24 13:50	6.3	---	0	0	---
7: TW Huronville South Treated Water	22-Apr-24 13:50	6.3	1.59	0	0	< 10
8: RW Murdock Glen Raw Water	22-Apr-24 13:20	6.3	---	0	0	---
9: TW Murdock Glen Treated Water	22-Apr-24 13:20	6.3	1.59	0	0	< 10
10: RW Blairs Grove Raw Water	22-Apr-24 12:50	6.3	---	0	0	---
11: TW Blairs Grove Treated Water	22-Apr-24 12:45	6.3	1.14	0	0	< 10
12: RW Point Clark Raw Water #2	22-Apr-24 12:05	6.3	---	0	0	---
13: RW Point Clark Raw Water #3	22-Apr-24 12:00	6.3	---	0	0	---
14: TW Point Clark Treated Water	22-Apr-24 11:55	6.3	1.62	0	0	< 10
15: DW DW - Amberley Beach SS	22-Apr-24 11:45	6.3	1.41	0	0	< 10
16: DW DW Chem Shed	22-Apr-24 12:20	6.3	1.33	0	0	10
17: DW DW Bruce Beach	22-Apr-24 13:15	6.3	1.58	0	0	---
18: DW DW Inverlyn CH	22-Apr-24 13:40	6.3	1.40	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Cristal Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA21231-APR24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

19-April-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

Date Rec. : 16 April 2024  
 LR Report: CA20838-APR24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	17-Apr-24	17-Apr-24	17-Apr-24
2: Analysis Start Time		---	---	14:05	14:05	13:40
3: Analysis Completed Date		---	---	19-Apr-24	19-Apr-24	19-Apr-24
4: Analysis Completed Time		---	---	14:15	14:15	14:15
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	16-Apr-24 13:05	12.8	---	0	0	---
7: TW Huronville South Treated Water	16-Apr-24 12:58	12.8	1.68	0	0	< 10
8: RW Murdock Glen Raw Water	16-Apr-24 12:39	12.8	---	0	0	---
9: TW Murdock Glen Treated Water	16-Apr-24 12:35	12.8	1.59	0	0	< 10
10: RW Blairs Grove Raw Water	16-Apr-24 12:00	12.8	---	0	0	---
11: TW Blairs Grove Treated Water	16-Apr-24 11:55	12.8	1.35	0	0	< 10
12: RW Point Clark Raw Water #2	16-Apr-24 11:40	12.8	---	0	0	---
13: RW Point Clark Raw Water #3	16-Apr-24 11:43	12.8	---	0	0	---
14: TW Point Clark Treated Water	16-Apr-24 11:30	12.8	1.55	0	0	< 10
15: DW DW-Amberley Beach SS	16-Apr-24 11:15	12.8	1.37	0	0	10
16: DW DW Inverlyn CH	16-Apr-24 13:15	12.8	1.44	0	0	< 10
17: DW DW Bruce Beach SS	16-Apr-24 12:20	12.8	1.54	0	0	---
18: DW DW Chem Shed	16-Apr-24 12:10	12.8	1.35	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Cristal Schuster**  
 Project Specialist-London,





**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20838-APR24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

12-April-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

Date Rec. : 09 April 2024  
 LR Report: CA20466-APR24

100 Cove Rd., Goderich  
 Canada, N7A 3Z2  
 Phone: 519-524-6583, Fax:519-524-9358

Copy: #1

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	10-Apr-24	10-Apr-24	10-Apr-24
2: Analysis Start Time		---	---	09:40	09:40	09:10
3: Analysis Completed Date		---	---	12-Apr-24	12-Apr-24	12-Apr-24
4: Analysis Completed Time		---	---	11:19	11:19	11:19
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	08-Apr-24 10:35	7.4	---	0	0	---
7: TW Huronville South Treated Water	08-Apr-24 10:40	7.4	1.67	0	0	< 10
8: RW Murdock Glen Raw Water	08-Apr-24 11:05	7.4	---	0	0	---
9: TW Murdock Glen Treated Water	08-Apr-24 11:00	7.4	1.71	0	0	< 10
10: RW Blairs Grove Raw Water	08-Apr-24 12:05	7.4	---	0	0	---
11: TW Blairs Grove Treated Water	08-Apr-24 12:05	7.4	1.53	0	0	< 10
12: RW Point Clark Raw Water #2	08-Apr-24 12:35	7.4	---	0	0	---
13: RW Point Clark Raw Water #3	08-Apr-24 12:35	7.4	---	0	0	---
14: TW Point Clark Treated Water	08-Apr-24 12:25	7.4	1.61	0	0	< 10
15: DW DW - Amberley Beach SS	08-Apr-24 13:25	7.4	1.48	0	0	< 10
16: DW DW Inverlyn CH	08-Apr-24 10:30	7.4	1.52	0	0	< 10
17: DW DW Bruce Beach	08-Apr-24 11:20	7.4	1.68	0	0	---
18: DW DW Chem Shed	08-Apr-24 12:15	7.4	1.48	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code	Reference Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001	OMOE MICROMFDC-E3407A
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002	SM 9215C
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001	OMOE MICROMFDC-E3407A

Angela Stott, B.Sc.  
 Branch Manager-London  
 Environment, Health & Safety

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

05-April-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

Date Rec. : 02 April 2024  
 LR Report: CA20095-APR24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	03-Apr-24	03-Apr-24	03-Apr-24
2: Analysis Start Time		---	---	10:15	10:15	09:50
3: Analysis Completed Date		---	---	05-Apr-24	05-Apr-24	05-Apr-24
4: Analysis Completed Time		---	---	10:03	10:03	10:03
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	01-Apr-24 12:50	6.0	---	0	0	---
7: TW Huronville South Treated Water	01-Apr-24 12:50	6.0	1.65	0	0	< 10
8: RW Murdock Glen Raw	01-Apr-24 13:10	6.0	---	0	0	---
9: TW Murdock Glen Treated	01-Apr-24 13:05	6.0	1.88	0	0	< 10
10: RW Blairs Grove Raw Water	01-Apr-24 14:05	6.0	---	0	0	---
11: TW Blairs Grove Treated Water	01-Apr-24 14:00	6.0	1.47	0	0	< 10
12: RW Point Clark Raw Water #2	01-Apr-24 14:40	6.0	---	0	0	---
13: RW Point Clark Raw Water #3	01-Apr-24 14:40	6.0	---	0	0	---
14: TW Point Clark Treated Water	01-Apr-24 14:35	6.0	1.71	0	0	< 10
15: DW DW Amberley Beach SS	01-Apr-24 15:00	6.0	1.66	0	0	< 10
16: DW DW Inverlyn CH	01-Apr-24 12:00	6.0	1.39	0	0	< 10
17: DW DW Bruce Beach	01-Apr-24 13:25	6.0	1.66	0	0	---
18: DW DW Chem Shed	01-Apr-24 14:25	6.0	1.37	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



**Cristal Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20095-APR24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

01-April-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

Date Rec. : 26 March 2024  
 LR Report: CA21113-MAR24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	27-Mar-24	27-Mar-24	27-Mar-24
2: Analysis Start Time		---	---	16:25	16:25	15:40
3: Analysis Completed Date		---	---	30-Mar-24	30-Mar-24	30-Mar-24
4: Analysis Completed Time		---	---	15:57	15:57	15:57
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	26-Mar-24 11:59	9.2	---	0	0	---
7: TW Huronville South Treated Water	26-Mar-24 11:57	9.2	1.53	0	0	< 10
8: RW Murdock Glen Raw Water	26-Mar-24 11:29	9.2	---	0	0	---
9: TW Murdock Glen Treated Water	26-Mar-24 11:26	9.2	1.69	0	0	< 10
10: RW Blairs Grove Raw Water	26-Mar-24 10:57	9.2	---	0	0	---
11: TW Blairs Grove Treated Water	26-Mar-24 10:54	9.2	1.40	0	0	< 10
12: RW Point Clark Raw Water #2	26-Mar-24 10:28	9.2	---	0	0	---
13: RW Point Clark Raw Water #3	26-Mar-24 10:29	9.2	---	0	0	---
14: TW Point Clark Treated Water	26-Mar-24 10:25	9.2	1.59	0	0	< 10
15: DW DW - Amberley Beach SS	26-Mar-24 10:41	9.2	1.44	0	0	10
16: DW DW - Inverlyn CH	26-Mar-24 11:45	9.2	1.39	0	0	< 10
17: DW DW - Chem Shed	26-Mar-24 11:05	9.2	1.45	0	0	---
18: DW DW - Bruce Beach SS	26-Mar-24 11:16	9.2	1.48	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



**Cristal Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA21113-MAR24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

22-March-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

Date Rec. : 19 March 2024  
 LR Report: CA20821-MAR24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	20-Mar-24	20-Mar-24	20-Mar-24
2: Analysis Start Time		---	---	---	13:40	13:40	13:00
3: Analysis Completed Date		---	---	---	22-Mar-24	22-Mar-24	22-Mar-24
4: Analysis Completed Time		---	---	---	13:08	13:08	13:08
5: MAC		---	---	---	0	0	---
6: RW Huronville South Raw Water	19-Mar-24 10:45	9.2	---	0.17	0	0	---
7: TW Huronville South Treated Water	19-Mar-24 10:45	9.2	1.51	0.21	0	0	< 10
8: RW Murdock Glen Raw Water	19-Mar-24 10:25	9.2	---	0.19	0	0	---
9: TW Murdock Glen Treated Water	19-Mar-24 10:25	9.2	1.66	0.22	0	0	< 10
10: RW Blairs Grove Raw Water	19-Mar-24 10:05	9.2	---	0.39	0	0	---
11: TW Blairs Grove Treated Water	19-Mar-24 10:05	9.2	1.41	0.33	0	0	< 10
12: RW Point Clark Raw Water #2	19-Mar-24 09:30	9.2	---	0.33	0	0	---
13: RW Point Clark Raw Water #3	19-Mar-24 09:35	9.2	---	0.37	0	0	---
14: TW Point Clark Treated Water	19-Mar-24 09:30	9.2	1.95	0.27	0	0	< 10
15: DW DW - Amberley Beach SS	19-Mar-24 09:20	9.2	1.47	---	0	0	10
16: DW DW - Amberley Store	19-Mar-24 09:10	9.2	1.38	---	0	0	< 10
17: DW DW - Chem Shed	19-Mar-24 10:00	9.2	1.33	---	0	0	---
18: DW DW - Inverlyn CH	19-Mar-24 10:55	9.2	1.31	---	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



**Cristal Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20821-MAR24

*Environment, Health & Safety*



**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

15-March-2024

**Veolia Water (Lakeshore)**

Attn : Steve Walmsley

Date Rec. : 12 March 2024  
 LR Report: CA20493-MAR24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	13-Mar-24	13-Mar-24	13-Mar-24
2: Analysis Start Time		---	---	10:10	10:10	09:35
3: Analysis Completed Date		---	---	15-Mar-24	15-Mar-24	15-Mar-24
4: Analysis Completed Time		---	---	10:18	10:18	10:18
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	11-Mar-24 11:25	9.2	---	0	0	---
7: TW Huronville South Treated Water	11-Mar-24 11:20	9.2	1.43	0	0	< 10
8: RW Murdock Glen Raw Water	11-Mar-24 11:42	9.2	---	0	0	---
9: TW Murdock Glen Treated Water	11-Mar-24 11:42	9.2	1.55	0	0	< 10
10: RW Blairs Grove Raw Water	11-Mar-24 12:00	9.2	---	0	0	---
11: TW Blairs Grove Treated Water	11-Mar-24 12:02	9.2	1.46	0	0	< 10
12: RW Point Clark Raw Water #2	11-Mar-24 12:30	9.2	---	0	0	---
13: RW Point Clark Raw Water #3	11-Mar-24 12:30	9.2	---	0	0	---
14: TW Point Clark Treated Water	11-Mar-24 12:20	9.2	1.72	0	0	< 10
15: DW DW-Amberley Beach SS	11-Mar-24 12:40	9.2	1.46	0	0	20
16: DW DW Chem Shed	11-Mar-24 12:10	9.2	1.36	0	0	10
17: DW DW Bruce Beach SS	11-Mar-24 11:35	9.2	1.26	0	0	---
18: DW DW CH Center	11-Mar-24 11:10	9.2	1.29	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Crista Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20493-MAR24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

08-March-2024

**Veolia Water (Lakeshore)**

Attn : Gary Nicholson

Date Rec. : 05 March 2024  
 LR Report: CA20201-MAR24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	06-Mar-24	06-Mar-24	06-Mar-24
2: Analysis Start Time		---	---	09:45	09:45	09:20
3: Analysis Completed Date		---	---	08-Mar-24	08-Mar-24	08-Mar-24
4: Analysis Completed Time		---	---	10:43	10:43	10:43
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	04-Mar-24 10:40	8.5	---	0	0	---
7: TW Huronville South Treated Water	04-Mar-24 10:40	8.5	1.54	0	0	< 10
8: RW Murdock Glen Raw Water	04-Mar-24 11:05	8.5	---	0	0	---
9: TW Murdock Glen Treated Water	04-Mar-24 11:00	8.5	1.47	0	0	< 10
10: RW Blairs Grove Raw Water	04-Mar-24 11:45	8.5	---	0	0	---
11: TW Blairs Grove Treated Water	04-Mar-24 11:45	8.5	1.46	0	0	< 10
12: RW Point Clark Raw Water #2	04-Mar-24 12:45	8.5	---	0	0	---
13: RW Point Clark Raw Water #3	04-Mar-24 12:45	8.5	---	0	0	---
14: TW Point Clark Treated Water	04-Mar-24 12:40	8.5	1.70	0	0	< 10
15: DW DW - Amberley Beach SS	04-Mar-24 13:10	8.5	1.65	0	0	< 10
16: DW DW Inverlyn CH	04-Mar-24 10:30	8.5	1.47	0	0	< 10
17: DW DW Bruce Beach	04-Mar-24 11:25	8.5	1.43	0	0	---
18: DW DW Chem Shed	04-Mar-24 12:05	8.5	1.37	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



**Cristal Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20201-MAR24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

01-March-2024

**Veolia Water (Lakeshore)**

Attn : Gary Nicholson

**Date Rec. :** 27 February 2024  
**LR Report:** CA21081-FEB24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

**Copy:** #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	28-Feb-24	28-Feb-24	28-Feb-24
2: Analysis Start Time		---	---	09:50	09:50	09:15
3: Analysis Completed Date		---	---	01-Mar-24	01-Mar-24	01-Mar-24
4: Analysis Completed Time		---	---	10:13	10:13	10:13
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	26-Feb-24 12:00	7.3	---	0	0	---
7: TW Huronville South Treated Water	26-Feb-24 11:55	7.3	1.54	0	0	< 10
8: RW Murdock Glen Raw Water	26-Feb-24 12:20	7.3	---	0	0	---
9: TW Murdock Glen Treated Water	26-Feb-24 12:20	7.3	1.52	0	0	< 10
10: RW Blairs Grove Raw Water	26-Feb-24 12:35	7.3	---	0	0	---
11: TW Blairs Grove Treated Water	26-Feb-24 12:35	7.3	1.40	0	0	10
12: RW Point Clark Raw Water #2	26-Feb-24 12:55	7.3	---	0	0	---
13: RW Point Clark Raw Water #3	26-Feb-24 13:00	7.3	---	0	0	---
14: TW Point Clark Treated Water	26-Feb-24 13:00	7.3	1.76	0	0	< 10
15: DW DW Inverlyn CH	26-Feb-24 11:45	7.3	1.50	0	0	< 10
16: DW DW Amberley Beach SS	26-Feb-24 13:10	7.3	1.29	0	0	< 10
17: DW DW Bruce Beach SS	26-Feb-24 12:10	7.3	1.39	0	0	---
18: DW DW Chem Shed	26-Feb-24 12:45	7.3	1.62	0	0	---

MAC - Maximum Acceptable Concentration

**Angela Stott, B.Sc.**  
 Branch Manager-London  
 Environment, Health & Safety

**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA21081-FEB24

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

23-February-2024

**Veolia Water (Lakeshore)**

Attn : Gary Nicholson

**Date Rec. :** 20 February 2024  
**LR Report:** CA20741-FEB24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

**Copy:** #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	21-Feb-24	21-Feb-24	21-Feb-24
2: Analysis Start Time		---	---	12:30	12:30	11:35
3: Analysis Completed Date		---	---	23-Feb-24	23-Feb-24	23-Feb-24
4: Analysis Completed Time		---	---	11:22	11:22	11:22
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	20-Feb-24 09:50	8.1	---	0	0	---
7: TW Huronville South Treated Water	20-Feb-24 09:45	8.1	1.50	0	0	< 10
8: RW Murdock Glen Raw Water	20-Feb-24 10:05	8.1	---	0	0	---
9: TW Murdock Glen Treated Water	20-Feb-24 10:00	8.1	1.51	0	0	< 10
10: RW Blairs Grove Raw Water	20-Feb-24 10:30	8.1	---	0	0	---
11: TW Blairs Grove Treated Water	20-Feb-24 10:30	8.1	1.46	0	0	< 10
12: RW Point Clark Raw Water #2	20-Feb-24 10:55	8.1	---	0	0	---
13: RW Point Clark Raw Water #3	20-Feb-24 10:55	8.1	---	0	0	---
14: TW Point Clark Treated Water	20-Feb-24 10:50	8.1	1.74	0	0	< 10
15: DW DW-Amberley Beach SS	20-Feb-24 11:10	8.1	1.58	0	0	< 10
16: DW DW Inverlyn CH	20-Feb-24 09:40	8.1	1.45	0	0	< 10
17: DW DW 702 Lake Range	20-Feb-24 10:15	8.1	1.33	0	0	---
18: DW DW Chem Shed	20-Feb-24 10:40	8.1	1.37	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**Crista Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20741-FEB24

*Environment, Health & Safety*





SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

16-February-2024

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 13 February 2024
LR Report: CA20492-FEB24

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
Fax:519-524-9358

CERTIFICATE OF ANALYSIS
Final Report

Table with 7 columns: Sample ID, Sample Date & Time, Temperature Upon Receipt °C, Field ResCI Free mg/L, Total Coliform cfu/100mL, E.Coli cfu/100mL, Heterotrophic Plate Count (HPC) cfu/1mL. Rows include analysis start/completed dates and times, MAC, and 18 samples of raw and treated water from various locations.

MAC - Maximum Acceptable Concentration

Method Descriptions

Table with 3 columns: Units, Description, SGS Method Code. Rows describe E.Coli by MF, Heterotrophic Plate Count (HPC) by SP, and Total Coliform by MF.

Handwritten signature



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20492-FEB24

---

*Cristal Schuster  
Project Specialist-London,  
Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

09-February-2024

**Veolia Water (Lakeshore)**

Attn : Gary Nicholson

**Date Rec. :** 06 February 2024  
**LR Report:** CA20222-FEB24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

**Copy:** #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	07-Feb-24	07-Feb-24	07-Feb-24
2: Analysis Start Time		---	---	10:00	10:00	09:35
3: Analysis Completed Date		---	---	09-Feb-24	09-Feb-24	09-Feb-24
4: Analysis Completed Time		---	---	11:09	11:09	11:09
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	05-Feb-24 15:50	2.8	---	0	0	---
7: TW Huronville South Treated Water	05-Feb-24 15:55	2.8	1.56	0	0	< 10
8: RW Murdock Glen Raw Water	05-Feb-24 15:23	2.8	---	0	0	---
9: TW Murdock Glen Treated Water	05-Feb-24 15:20	2.8	1.71	0	0	< 10
10: RW Blairs Grove Raw Water	05-Feb-24 14:25	2.8	---	0	0	---
11: TW Blairs Grove Treated Water	05-Feb-24 14:30	2.8	1.47	0	0	< 10
12: RW Point Clark Raw Water #2	05-Feb-24 13:12	2.8	---	0	0	---
13: RW Point Clark Raw Water #3	05-Feb-24 13:10	2.8	---	0	0	---
14: TW Point Clark Treated Water	05-Feb-24 13:00	2.8	1.71	0	0	< 10
15: DW DW Amberley Beach SS	05-Feb-24 13:25	2.8	1.61	0	0	< 10
16: DW DW Inverlyn CH	05-Feb-24 16:05	2.8	1.43	0	0	< 10
17: DW DW Bruce Beach SS	05-Feb-24 15:10	2.8	1.60	0	0	---
18: DW DW Chem Shed	05-Feb-24 14:50	2.8	1.57	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Crista Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20222-FEB24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

02-February-2024

**Veolia Water (Lakeshore)**

Attn : Gary Nicholson

Date Rec. : 30 January 2024  
 LR Report: CA21260-JAN24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	31-Jan-24	31-Jan-24	31-Jan-24
2: Analysis Start Time		---	---	09:25	09:25	09:05
3: Analysis Completed Date		---	---	01-Feb-24	01-Feb-24	02-Feb-24
4: Analysis Completed Time		---	---	16:39	16:39	10:45
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	29-Jan-24 13:15	5.0	---	0	0	---
7: TW Huronville South Treated Water	29-Jan-24 13:20	5.0	1.48	0	0	< 10
8: RW Murdock Glen Raw Water	29-Jan-24 14:05	5.0	---	0	0	---
9: TW Murdock Glen Treated Water	29-Jan-24 14:05	5.0	1.69	0	0	< 10
10: RW Blairs Grove Raw Water	29-Jan-24 14:20	5.0	---	0	0	---
11: TW Blairs Grove Treated Water	29-Jan-24 14:20	5.0	1.48	0	0	< 10
12: RW Point Clark Raw Water #2	29-Jan-24 15:05	5.0	---	0	0	---
13: RW Point Clark Raw Water #3	29-Jan-24 15:05	5.0	---	0	0	---
14: TW Point Clark Treated Water	29-Jan-24 15:05	5.0	1.73	0	0	< 10
15: DW DW - Amberley Beach SS	29-Jan-24 15:15	5.0	1.62	0	0	< 10
16: DW DW Inverlyn CH	29-Jan-24 13:40	5.0	1.39	0	0	< 10
17: DW DW Bruce Beach SS	29-Jan-24 13:55	5.0	1.26	0	0	---
18: DW DW Chem Shed	29-Jan-24 14:45	5.0	1.35	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Cristal Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA21260-JAN24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

26-January-2024

**Veolia Water (Lakeshore)**

Attn : Gary Nicholson

**Date Rec. :** 23 January 2024  
**LR Report:** CA21007-JAN24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

**Copy:** #1

Phone: 519-524-6583  
 Fax:519-524-9358

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	24-Jan-24	24-Jan-24	24-Jan-24
2: Analysis Start Time		---	---	09:45	09:45	09:15
3: Analysis Completed Date		---	---	26-Jan-24	26-Jan-24	26-Jan-24
4: Analysis Completed Time		---	---	10:11	10:11	10:11
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	22-Jan-24 11:15	3.3	---	0	0	---
7: TW Huronville South Treated Water	22-Jan-24 11:10	3.3	1.49	0	0	< 10
8: RW Murdock Glen Raw Water	22-Jan-24 11:45	3.3	---	0	0	---
9: TW Murdock Glen Treated Water	22-Jan-24 11:50	3.3	1.66	0	0	< 10
10: RW Blairs Grove Raw Water	22-Jan-24 12:10	3.3	---	0	0	---
11: TW Blairs Grove Treated Water	22-Jan-24 12:10	3.3	1.44	0	0	< 10
12: RW Point Clark Raw Water #2	22-Jan-24 12:50	3.3	---	0	0	---
13: RW Point Clark Raw Water #3	22-Jan-24 12:50	3.3	---	0	0	---
14: TW Point Clark Treated Water	22-Jan-24 12:40	3.3	1.80	0	0	< 10
15: DW DW Pt Clark CC	22-Jan-24 12:30	3.3	1.30	0	0	< 10
16: DW DW CH Inverlyn	22-Jan-24 11:00	3.3	1.32	0	0	< 10
17: DW DW Chem Shed	22-Jan-24 12:20	3.3	1.42	0	0	---
18: DW DW Amberley Beach St	22-Jan-24 13:05	3.3	1.65	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Cristal Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA21007-JAN24

*Environment, Health & Safety*



**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

19-January-2024

**Veolia Water (Lakeshore)**

Attn : Gary Nicholson

**Date Rec. :** 16 January 2024  
**LR Report:** CA20718-JAN24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

**Copy:** #1

Phone: 519-524-6583  
 Fax:519-524-9358

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	17-Jan-24	17-Jan-24	17-Jan-24
2: Analysis Start Time		---	---	09:30	09:30	09:10
3: Analysis Completed Date		---	---	19-Jan-24	19-Jan-24	19-Jan-24
4: Analysis Completed Time		---	---	10:33	10:33	10:33
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	15-Jan-24 12:18	8.9	---	0	0	---
7: TW Huronville South Treated Water	15-Jan-24 12:14	8.9	1.85	0	0	< 10
8: RW Murdock Glen Raw Water	15-Jan-24 15:55	8.9	---	0	0	---
9: TW Murdock Glen Treated Water	15-Jan-24 15:50	8.9	1.71	0	0	< 10
10: RW Blairs Grove Raw Water	15-Jan-24 14:53	8.9	---	0	0	---
11: TW Blairs Grove Treated Water	15-Jan-24 14:50	8.9	1.48	0	0	< 10
12: RW Point Clark Raw Water #2	15-Jan-24 13:44	8.9	---	0	0	---
13: RW Point Clark Raw Water #3	15-Jan-24 13:45	8.9	---	0	0	---
14: TW Point Clark Treated Water	15-Jan-24 13:40	8.9	1.78	0	0	< 10
15: DW DW - Amberley Beach SS	15-Jan-24 14:25	8.9	1.58	0	0	< 10
16: DW DW - Inverlyn Clubhouse	15-Jan-24 11:40	8.9	1.86	0	0	< 10
17: DW DW - Bruce Beach SS	15-Jan-24 15:30	8.9	1.58	0	0	---
18: DW DW - Chem Shed	15-Jan-24 15:05	8.9	1.53	0	0	---

MAC - Maximum Acceptable Concentration

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**Crista Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20718-JAN24

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

12-January-2024

**Veolia Water (Lakeshore)**

Attn : Gary Nicholson

**Date Rec. :** 09 January 2024  
**LR Report:** CA20456-JAN24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

**Copy:** #1

Phone: 519-524-6583  
 Fax:519-524-9358

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	10-Jan-24	10-Jan-24	10-Jan-24
2: Analysis Start Time		---	---	14:45	14:45	14:20
3: Analysis Completed Date		---	---	11-Jan-24	11-Jan-24	12-Jan-24
4: Analysis Completed Time		---	---	17:30	17:30	12:27
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	09-Jan-24 10:15	9.6	---	0	0	---
7: TW Huronville South Treated Water	09-Jan-24 10:15	9.6	1.85	0	0	< 10
8: RW Murdock Glen Raw Water	09-Jan-24 09:45	9.6	---	0	0	---
9: TW Murdock Glen Treated Water	09-Jan-24 09:45	9.6	1.67	0	0	< 10
10: RW Blairs Grove Raw Water	09-Jan-24 09:15	9.6	---	0	0	---
11: TW Blairs Grove Treated Water	09-Jan-24 09:15	9.6	1.41	0	0	< 10
12: RW Point Clark Raw Water #2	09-Jan-24 09:00	9.6	---	0	0	---
13: RW Point Clark Raw Water #3	09-Jan-24 09:00	9.6	---	0	0	---
14: TW Point Clark Treated Water	09-Jan-24 08:55	9.6	1.64	0	0	< 10
15: DW DW - Amberley Beach SS	09-Jan-24 08:40	9.6	1.57	0	0	< 10
16: DW DW Chem Shed	09-Jan-24 09:10	9.6	1.35	0	0	< 10
17: DW DW Bruce Beach	09-Jan-24 09:35	9.6	1.32	0	0	---
18: DW DW Inverlyn	09-Jan-24 10:05	9.6	1.26	0	0	---

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.  
 Branch Manager-London  
 Environment, Health & Safety

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

05-January-2024

**Veolia Water (Lakeshore)**

Attn : Gary Nicholson

**Date Rec. :** 02 January 2024  
**LR Report:** CA20095-JAN24

100 Cove Rd.  
 Goderich, ON  
 N7A 3Z2, Canada

**Copy:** #1

Phone: 519-524-6583  
 Fax:519-524-9358

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	03-Jan-24	03-Jan-24	03-Jan-24
2: Analysis Start Time		---	---	13:15	13:15	12:50
3: Analysis Completed Date		---	---	05-Jan-24	05-Jan-24	05-Jan-24
4: Analysis Completed Time		---	---	09:41	09:41	11:29
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	02-Jan-24 11:15	8.6	---	0	0	---
7: TW Huronville South Treated Water	02-Jan-24 11:15	8.6	1.58	0	0	< 10
8: RW Murdock Glen Raw Water	02-Jan-24 11:45	8.6	---	0	0	---
9: TW Murdock Glen Treated Water	02-Jan-24 11:45	8.6	1.71	0	0	< 10
10: RW Blairs Grove Raw Water	02-Jan-24 12:00	8.6	---	0	0	---
11: TW Blairs Grove Treated Water	02-Jan-24 12:00	8.6	1.40	0	0	< 10
12: RW Point Clark Raw Water #2	02-Jan-24 12:25	8.6	---	0	0	---
13: RW Point Clark Raw Water #3	02-Jan-24 12:25	8.6	---	0	0	---
14: TW Point Clark Treated Water	02-Jan-24 12:30	8.6	1.66	0	0	< 10
15: DW DW - Amberley Beach SS	02-Jan-24 12:40	8.6	1.47	0	0	< 10
16: DW DW Inverlyn CH	02-Jan-24 11:00	8.6	1.08	0	0	< 10
17: DW DW Bruce Beach SS	02-Jan-24 11:30	8.6	1.38	0	0	---
18: DW DW Chem Shed	02-Jan-24 12:15	8.6	1.47	0	0	---

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.  
 Branch Manager-London  
 Environment, Health & Safety

**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20095-JAN24

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001