



Works #: 220002663

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

31-March-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 25 March 2025
LR Report: CA21187-MAR25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				26-Mar-25	26-Mar-25	26-Mar-25
2: Analysis Start Time				16:55	16:55	16:25
3: Analysis Completed Date				28-Mar-25	28-Mar-25	28-Mar-25
4: Analysis Completed Time				18:13	18:13	18:13
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	25-Mar-25 08:45	8.1	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	25-Mar-25 08:55	8.1	1.72	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	25-Mar-25 08:28	8.1	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	25-Mar-25 08:23	8.1	1.85	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	25-Mar-25 09:24	8.1	1.53	0	0	< 10
11: DW DW-Lucknow Tower	25-Mar-25 09:12	8.1	1.31	0	0	< 10
12: DW DW-Lucknow SPS	25-Mar-25 07:54	8.1	1.33	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

21-March-2025

OCWA-Huron Kinloss (Lucknow DWS)
Attn : Paul Sherban

Date Rec. : 18 March 2025
LR Report: CA20886-MAR25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				19-Mar-25	19-Mar-25	19-Mar-25
2: Analysis Start Time				15:55	15:55	15:15
3: Analysis Completed Date				21-Mar-25	21-Mar-25	21-Mar-25
4: Analysis Completed Time				14:17	14:17	14:17
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	18-Mar-25 10:19	11.9	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	18-Mar-25 10:25	11.9	1.51	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	18-Mar-25 10:11	11.9	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	18-Mar-25 10:09	11.9	1.71	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	18-Mar-25 08:43	11.9	1.30	0	0	< 10
11: DW DW-Lucknow Tower	18-Mar-25 10:36	11.9	1.40	0	0	10
12: DW DW-Lucknow SPS	18-Mar-25 09:55	11.9	1.35	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

14-March-2025

OCWA-Huron Kinloss (Lucknow DWS)
Attn : Paul Sherban

Date Rec. : 11 March 2025
LR Report: CA20511-MAR25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				12-Mar-25	12-Mar-25	12-Mar-25
2: Analysis Start Time				13:55	13:55	13:30
3: Analysis Completed Date				14-Mar-25	14-Mar-25	14-Mar-25
4: Analysis Completed Time				12:52	12:52	12:52
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	11-Mar-25 11:52	8.3	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	11-Mar-25 11:47	8.3	1.48	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	11-Mar-25 10:37	8.3	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	11-Mar-25 10:32	8.3	1.60	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	11-Mar-25 09:43	8.3	1.47	0	0	< 10
11: DW DW-Lucknow Tower	11-Mar-25 12:14	8.3	1.36	0	0	< 10
12: DW DW-Lucknow SPS	11-Mar-25 09:55	8.3	1.33	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety



Works #: 220002663

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

07-March-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 04 March 2025
LR Report: CA20181-MAR25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				05-Mar-25	05-Mar-25	05-Mar-25
2: Analysis Start Time				15:45	15:45	15:00
3: Analysis Completed Date				07-Mar-25	07-Mar-25	07-Mar-25
4: Analysis Completed Time				14:21	14:21	14:21
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	04-Mar-25 10:16	8.6	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	04-Mar-25 10:09	8.6	1.47	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	04-Mar-25 09:38	8.6	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	04-Mar-25 09:45	8.6	1.61	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	04-Mar-25 11:14	8.6	1.39	0	0	< 10
11: DW DW-Lucknow Tower	04-Mar-25 10:56	8.6	1.38	0	0	< 10
12: DW DW-Lucknow SPS	04-Mar-25 09:31	8.6	1.55	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Crista Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002663

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

28-February-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 25 February 2025
LR Report: CA21178-FEB25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	26-Feb-25	26-Feb-25	26-Feb-25
2: Analysis Start Time		---	---	12:50	12:50	12:25
3: Analysis Completed Date		---	---	28-Feb-25	28-Feb-25	28-Feb-25
4: Analysis Completed Time		---	---	10:52	10:52	10:52
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	25-Feb-25 09:30	7.8	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	25-Feb-25 09:35	7.8	1.58	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	25-Feb-25 09:21	7.8	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	25-Feb-25 09:16	7.8	1.80	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002663

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

28-February-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 25 February 2025
LR Report: CA21179-FEB25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	26-Feb-25	26-Feb-25	26-Feb-25
2: Analysis Start Time		---	---	12:50	12:50	12:25
3: Analysis Completed Date		---	---	28-Feb-25	28-Feb-25	28-Feb-25
4: Analysis Completed Time		---	---	10:58	10:58	10:58
5: MAC		---	---	0	0	---
6: DW DW-86667 Country Road 1 South (ACW)	25-Feb-25 09:51	7.8	1.50	0	0	< 10
7: DW DW-Lucknow Tower	25-Feb-25 09:43	7.8	1.45	0	0	< 10
8: DW DW-Lucknow SPS	25-Feb-25 09:59	7.8	1.59	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

24-February-2025

OCWA-Huron Kinloss (Lucknow DWS)
Attn : Paul Sherban

Date Rec. : 19 February 2025
LR Report: CA21040-FEB25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				20-Feb-25	20-Feb-25	20-Feb-25
2: Analysis Start Time				14:45	14:45	14:10
3: Analysis Completed Date				24-Feb-25	24-Feb-25	24-Feb-25
4: Analysis Completed Time				10:50	10:50	10:50
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	19-Feb-25 09:22	10.8	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	19-Feb-25 09:28	10.8	1.60	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	19-Feb-25 10:20	10.8	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	19-Feb-25 10:15	10.8	1.76	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	19-Feb-25 10:00	10.8	1.53	0	0	< 10
11: DW DW-Lucknow Tower	19-Feb-25 09:47	10.8	1.21	0	0	< 10
12: DW DW-Lucknow SPS	19-Feb-25 10:43	10.8	1.46	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety



Works #: 220002663

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

18-February-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 11 February 2025
LR Report: CA20760-FEB25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				12-Feb-25	12-Feb-25	12-Feb-25
2: Analysis Start Time				17:10	17:10	16:45
3: Analysis Completed Date				14-Feb-25	14-Feb-25	14-Feb-25
4: Analysis Completed Time				16:19	16:19	16:19
5: MAC		---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	11-Feb-25 11:05	5.6	1.39	0	0	< 10
7: DW DW-Lucknow Tower	11-Feb-25 10:12	5.6	1.37	0	0	< 10
8: DW DW-Lucknow SPS	11-Feb-25 10:56	5.6	1.44	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002663

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

18-February-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 11 February 2025
LR Report: CA20761-FEB25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date			---	12-Feb-25	12-Feb-25	12-Feb-25
2: Analysis Start Time			---	17:10	17:10	16:45
3: Analysis Completed Date			---	14-Feb-25	14-Feb-25	14-Feb-25
4: Analysis Completed Time			---	16:19	16:19	16:19
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	11-Feb-25 10:26	5.6	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	11-Feb-25 10:22	5.6	1.57	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	11-Feb-25 10:36	5.6	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	11-Feb-25 10:43	5.6	1.88	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002663

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

07-February-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 04 February 2025
LR Report: CA20196-FEB25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				05-Feb-25	05-Feb-25	05-Feb-25
2: Analysis Start Time				14:00	14:00	13:20
3: Analysis Completed Date				07-Feb-25	07-Feb-25	07-Feb-25
4: Analysis Completed Time				14:25	14:25	14:25
5: MAC		---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	04-Feb-25 10:59	8.0	1.49	0	0	< 10
7: DW DW-Lucknow Tower	04-Feb-25 12:24	8.0	1.39	0	0	< 10
8: DW DW-Lucknow SPS	04-Feb-25 11:19	8.0	1.17	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

07-February-2025

OCWA-Huron Kinloss (Lucknow DWS)
Attn : Paul Sherban

Date Rec. : 04 February 2025
LR Report: CA20197-FEB25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				05-Feb-25	05-Feb-25	05-Feb-25
2: Analysis Start Time				14:00	14:00	13:20
3: Analysis Completed Date				07-Feb-25	07-Feb-25	07-Feb-25
4: Analysis Completed Time				14:25	14:25	14:25
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	04-Feb-25 12:07	8.0	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	04-Feb-25 12:01	8.0	1.65	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	04-Feb-25 11:49	8.0	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	04-Feb-25 11:45	8.0	1.71	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

31-January-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 28 January 2025
LR Report: CA21227-JAN25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				29-Jan-25	29-Jan-25	29-Jan-25
2: Analysis Start Time				16:00	16:00	15:35
3: Analysis Completed Date				31-Jan-25	31-Jan-25	31-Jan-25
4: Analysis Completed Time				13:07	13:07	13:07
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	28-Jan-25 09:11	6.8	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	28-Jan-25 09:16	6.8	1.64	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	28-Jan-25 09:36	6.8	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	28-Jan-25 09:32	6.8	1.58	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	28-Jan-25 08:42	6.8	1.47	0	0	< 10
11: DW DW-Lucknow Tower	28-Jan-25 09:04	6.8	1.43	0	0	< 10
12: DW DW-Lucknow SPS	28-Jan-25 08:56	6.8	1.21	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

24-January-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 21 January 2025
LR Report: CA20942-JAN25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				22-Jan-25	22-Jan-25	22-Jan-25
2: Analysis Start Time				16:20	16:20	15:45
3: Analysis Completed Date				24-Jan-25	24-Jan-25	24-Jan-25
4: Analysis Completed Time				14:19	14:19	14:19
5: MAC		---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	21-Jan-25 09:39	4.9	1.49	0	0	< 10
7: DW DW-Lucknow Tower	21-Jan-25 10:01	4.9	1.41	0	0	< 10
8: DW DW-Office	21-Jan-25 11:04	4.9	1.21	0	0	---
9: RW RW1-Lucknow RW-Well 4	21-Jan-25 10:06	4.9	---	0	0	---
10: TW TW1-Lucknow TW-Well 4	21-Jan-25 10:12	4.9	1.50	0	0	< 10
11: RW RW2-Lucknow RW-Well 5	21-Jan-25 10:35	4.9	---	0	0	---
12: TW TW2-Lucknow TW-Well 5	21-Jan-25 10:27	4.9	1.28	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety



Works #: 220002663

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

17-January-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 14 January 2025
LR Report: CA20582-JAN25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				15-Jan-25	15-Jan-25	15-Jan-25
2: Analysis Start Time				15:00	15:00	14:35
3: Analysis Completed Date				17-Jan-25	17-Jan-25	17-Jan-25
4: Analysis Completed Time				12:42	12:42	12:42
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	14-Jan-25 09:38	6.0	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	14-Jan-25 09:29	6.0	1.50	0	0	10
8: RW RW2-Lucknow RW-Well 5	14-Jan-25 09:03	6.0	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	14-Jan-25 08:55	6.0	1.76	0	0	< 10
10: DW DW-86667 South (ACW)	14-Jan-25 08:43	6.0	1.47	0	0	10
11: DW DW-Lucknow SPS	14-Jan-25 08:33	6.0	1.51	0	0	< 10
12: DW DW-Old Firehall	14-Jan-25 08:10	6.0	1.62	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Crista Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

13-January-2025

OCWA-Huron Kinloss (Lucknow DWS)
Attn : Paul Sherban

Date Rec. : 08 January 2025
LR Report: CA20304-JAN25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	08-Jan-25	08-Jan-25	08-Jan-25
2: Analysis Start Time		---	---	18:50	18:50	18:20
3: Analysis Completed Date		---	---	10-Jan-25	10-Jan-25	10-Jan-25
4: Analysis Completed Time		---	---	17:41	17:41	17:41
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	07-Jan-25 09:35	3.4	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	07-Jan-25 09:30	3.4	1.48	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	07-Jan-25 08:30	3.4	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	07-Jan-25 08:24	3.4	1.75	0	0	< 10
10: DW DW-86667 South (ACW)	07-Jan-25 09:06	3.4	1.38	0	0	< 10
11: DW DW-Lucknow SPS	07-Jan-25 08:51	3.4	1.48	0	0	< 10
12: DW DW-Old Firehall	07-Jan-25 09:00	3.4	1.55	0	0	---
13: DW DW-Tower	07-Jan-25 09:20	3.4	1.42	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety