



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

15-March-2024

Veolia Water (Lakeshore)

Attn : Steve Walmsley

Date Rec. : 12 March 2024
 LR Report: CA20493-MAR24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	13-Mar-24	13-Mar-24	13-Mar-24
2: Analysis Start Time		---	---	10:10	10:10	09:35
3: Analysis Completed Date		---	---	15-Mar-24	15-Mar-24	15-Mar-24
4: Analysis Completed Time		---	---	10:18	10:18	10:18
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	11-Mar-24 11:25	9.2	---	0	0	---
7: TW Huronville South Treated Water	11-Mar-24 11:20	9.2	1.43	0	0	< 10
8: RW Murdock Glen Raw Water	11-Mar-24 11:42	9.2	---	0	0	---
9: TW Murdock Glen Treated Water	11-Mar-24 11:42	9.2	1.55	0	0	< 10
10: RW Blairs Grove Raw Water	11-Mar-24 12:00	9.2	---	0	0	---
11: TW Blairs Grove Treated Water	11-Mar-24 12:02	9.2	1.46	0	0	< 10
12: RW Point Clark Raw Water #2	11-Mar-24 12:30	9.2	---	0	0	---
13: RW Point Clark Raw Water #3	11-Mar-24 12:30	9.2	---	0	0	---
14: TW Point Clark Treated Water	11-Mar-24 12:20	9.2	1.72	0	0	< 10
15: DW DW-Amberley Beach SS	11-Mar-24 12:40	9.2	1.46	0	0	20
16: DW DW Chem Shed	11-Mar-24 12:10	9.2	1.36	0	0	10
17: DW DW Bruce Beach SS	11-Mar-24 11:35	9.2	1.26	0	0	---
18: DW DW CH Center	11-Mar-24 11:10	9.2	1.29	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Crista Schuster
 Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20493-MAR24

Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

08-March-2024

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 05 March 2024
LR Report: CA20201-MAR24

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	06-Mar-24	06-Mar-24	06-Mar-24
2: Analysis Start Time		---	---	09:45	09:45	09:20
3: Analysis Completed Date		---	---	08-Mar-24	08-Mar-24	08-Mar-24
4: Analysis Completed Time		---	---	10:43	10:43	10:43
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	04-Mar-24 10:40	8.5	---	0	0	---
7: TW Huronville South Treated Water	04-Mar-24 10:40	8.5	1.54	0	0	< 10
8: RW Murdock Glen Raw Water	04-Mar-24 11:05	8.5	---	0	0	---
9: TW Murdock Glen Treated Water	04-Mar-24 11:00	8.5	1.47	0	0	< 10
10: RW Blairs Grove Raw Water	04-Mar-24 11:45	8.5	---	0	0	---
11: TW Blairs Grove Treated Water	04-Mar-24 11:45	8.5	1.46	0	0	< 10
12: RW Point Clark Raw Water #2	04-Mar-24 12:45	8.5	---	0	0	---
13: RW Point Clark Raw Water #3	04-Mar-24 12:45	8.5	---	0	0	---
14: TW Point Clark Treated Water	04-Mar-24 12:40	8.5	1.70	0	0	< 10
15: DW DW - Amberley Beach SS	04-Mar-24 13:10	8.5	1.65	0	0	< 10
16: DW DW Inverlyn CH	04-Mar-24 10:30	8.5	1.47	0	0	< 10
17: DW DW Bruce Beach	04-Mar-24 11:25	8.5	1.43	0	0	---
18: DW DW Chem Shed	04-Mar-24 12:05	8.5	1.37	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Crista Schuster
Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20201-MAR24

Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

01-March-2024

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 27 February 2024
LR Report: CA21081-FEB24

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	28-Feb-24	28-Feb-24	28-Feb-24
2: Analysis Start Time		---	---	09:50	09:50	09:15
3: Analysis Completed Date		---	---	01-Mar-24	01-Mar-24	01-Mar-24
4: Analysis Completed Time		---	---	10:13	10:13	10:13
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	26-Feb-24 12:00	7.3	---	0	0	---
7: TW Huronville South Treated Water	26-Feb-24 11:55	7.3	1.54	0	0	< 10
8: RW Murdock Glen Raw Water	26-Feb-24 12:20	7.3	---	0	0	---
9: TW Murdock Glen Treated Water	26-Feb-24 12:20	7.3	1.52	0	0	< 10
10: RW Blairs Grove Raw Water	26-Feb-24 12:35	7.3	---	0	0	---
11: TW Blairs Grove Treated Water	26-Feb-24 12:35	7.3	1.40	0	0	10
12: RW Point Clark Raw Water #2	26-Feb-24 12:55	7.3	---	0	0	---
13: RW Point Clark Raw Water #3	26-Feb-24 13:00	7.3	---	0	0	---
14: TW Point Clark Treated Water	26-Feb-24 13:00	7.3	1.76	0	0	< 10
15: DW DW Inverlyn CH	26-Feb-24 11:45	7.3	1.50	0	0	< 10
16: DW DW Amberley Beach SS	26-Feb-24 13:10	7.3	1.29	0	0	< 10
17: DW DW Bruce Beach SS	26-Feb-24 12:10	7.3	1.39	0	0	---
18: DW DW Chem Shed	26-Feb-24 12:45	7.3	1.62	0	0	---

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA21081-FEB24

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

23-February-2024

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 20 February 2024
LR Report: CA20741-FEB24

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	21-Feb-24	21-Feb-24	21-Feb-24
2: Analysis Start Time		---	---	12:30	12:30	11:35
3: Analysis Completed Date		---	---	23-Feb-24	23-Feb-24	23-Feb-24
4: Analysis Completed Time		---	---	11:22	11:22	11:22
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	20-Feb-24 09:50	8.1	---	0	0	---
7: TW Huronville South Treated Water	20-Feb-24 09:45	8.1	1.50	0	0	< 10
8: RW Murdock Glen Raw Water	20-Feb-24 10:05	8.1	---	0	0	---
9: TW Murdock Glen Treated Water	20-Feb-24 10:00	8.1	1.51	0	0	< 10
10: RW Blairs Grove Raw Water	20-Feb-24 10:30	8.1	---	0	0	---
11: TW Blairs Grove Treated Water	20-Feb-24 10:30	8.1	1.46	0	0	< 10
12: RW Point Clark Raw Water #2	20-Feb-24 10:55	8.1	---	0	0	---
13: RW Point Clark Raw Water #3	20-Feb-24 10:55	8.1	---	0	0	---
14: TW Point Clark Treated Water	20-Feb-24 10:50	8.1	1.74	0	0	< 10
15: DW DW-Amberley Beach SS	20-Feb-24 11:10	8.1	1.58	0	0	< 10
16: DW DW Inverlyn CH	20-Feb-24 09:40	8.1	1.45	0	0	< 10
17: DW DW 702 Lake Range	20-Feb-24 10:15	8.1	1.33	0	0	---
18: DW DW Chem Shed	20-Feb-24 10:40	8.1	1.37	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Crista Schuster
Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20741-FEB24

Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

16-February-2024

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 13 February 2024
LR Report: CA20492-FEB24

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	14-Feb-24	14-Feb-24	14-Feb-24
2: Analysis Start Time		---	---	10:15	10:15	09:55
3: Analysis Completed Date		---	---	16-Feb-24	16-Feb-24	16-Feb-24
4: Analysis Completed Time		---	---	10:57	10:57	10:57
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	12-Feb-24 15:55	5.0	---	0	0	---
7: TW Huronville South Treated Water	12-Feb-24 15:45	5.0	1.52	0	0	< 10
8: RW Murdock Glen Raw Water	12-Feb-24 15:10	5.0	---	0	0	---
9: TW Murdock Glen Treated Water	12-Feb-24 15:05	5.0	1.63	0	0	< 10
10: RW Blairs Grove Raw Water	12-Feb-24 13:35	5.0	---	0	0	---
11: TW Blairs Grove Treated Water	12-Feb-24 13:30	5.0	1.42	0	0	< 10
12: RW Point Clark Raw Water #2	12-Feb-24 12:41	5.0	---	0	0	---
13: RW Point Clark Raw Water #3	12-Feb-24 12:44	5.0	---	0	0	---
14: TW Point Clark Treated Water	12-Feb-24 12:30	5.0	1.69	0	0	< 10
15: DW DW-Amberley Beach SS	12-Feb-24 11:45	5.0	1.58	0	0	< 10
16: DW DW Chem Shed	12-Feb-24 14:40	5.0	1.47	0	0	< 10
17: DW DW Bruce Beach SS	12-Feb-24 14:50	5.0	1.54	0	0	---
18: DW DW Inverlyn CH	12-Feb-24 16:05	5.0	1.46	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20492-FEB24

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

09-February-2024

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 06 February 2024
 LR Report: CA20222-FEB24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	07-Feb-24	07-Feb-24	07-Feb-24
2: Analysis Start Time		---	---	10:00	10:00	09:35
3: Analysis Completed Date		---	---	09-Feb-24	09-Feb-24	09-Feb-24
4: Analysis Completed Time		---	---	11:09	11:09	11:09
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	05-Feb-24 15:50	2.8	---	0	0	---
7: TW Huronville South Treated Water	05-Feb-24 15:55	2.8	1.56	0	0	< 10
8: RW Murdock Glen Raw Water	05-Feb-24 15:23	2.8	---	0	0	---
9: TW Murdock Glen Treated Water	05-Feb-24 15:20	2.8	1.71	0	0	< 10
10: RW Blairs Grove Raw Water	05-Feb-24 14:25	2.8	---	0	0	---
11: TW Blairs Grove Treated Water	05-Feb-24 14:30	2.8	1.47	0	0	< 10
12: RW Point Clark Raw Water #2	05-Feb-24 13:12	2.8	---	0	0	---
13: RW Point Clark Raw Water #3	05-Feb-24 13:10	2.8	---	0	0	---
14: TW Point Clark Treated Water	05-Feb-24 13:00	2.8	1.71	0	0	< 10
15: DW DW Amberley Beach SS	05-Feb-24 13:25	2.8	1.61	0	0	< 10
16: DW DW Inverlyn CH	05-Feb-24 16:05	2.8	1.43	0	0	< 10
17: DW DW Bruce Beach SS	05-Feb-24 15:10	2.8	1.60	0	0	---
18: DW DW Chem Shed	05-Feb-24 14:50	2.8	1.57	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Crista Schuster
 Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20222-FEB24

Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

02-February-2024

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 30 January 2024
 LR Report: CA21260-JAN24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	31-Jan-24	31-Jan-24	31-Jan-24
2: Analysis Start Time		---	---	09:25	09:25	09:05
3: Analysis Completed Date		---	---	01-Feb-24	01-Feb-24	02-Feb-24
4: Analysis Completed Time		---	---	16:39	16:39	10:45
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	29-Jan-24 13:15	5.0	---	0	0	---
7: TW Huronville South Treated Water	29-Jan-24 13:20	5.0	1.48	0	0	< 10
8: RW Murdock Glen Raw Water	29-Jan-24 14:05	5.0	---	0	0	---
9: TW Murdock Glen Treated Water	29-Jan-24 14:05	5.0	1.69	0	0	< 10
10: RW Blairs Grove Raw Water	29-Jan-24 14:20	5.0	---	0	0	---
11: TW Blairs Grove Treated Water	29-Jan-24 14:20	5.0	1.48	0	0	< 10
12: RW Point Clark Raw Water #2	29-Jan-24 15:05	5.0	---	0	0	---
13: RW Point Clark Raw Water #3	29-Jan-24 15:05	5.0	---	0	0	---
14: TW Point Clark Treated Water	29-Jan-24 15:05	5.0	1.73	0	0	< 10
15: DW DW - Amberley Beach SS	29-Jan-24 15:15	5.0	1.62	0	0	< 10
16: DW DW Inverlyn CH	29-Jan-24 13:40	5.0	1.39	0	0	< 10
17: DW DW Bruce Beach SS	29-Jan-24 13:55	5.0	1.26	0	0	---
18: DW DW Chem Shed	29-Jan-24 14:45	5.0	1.35	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21260-JAN24

Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

26-January-2024

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 23 January 2024
LR Report: CA21007-JAN24

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	24-Jan-24	24-Jan-24	24-Jan-24
2: Analysis Start Time		---	---	09:45	09:45	09:15
3: Analysis Completed Date		---	---	26-Jan-24	26-Jan-24	26-Jan-24
4: Analysis Completed Time		---	---	10:11	10:11	10:11
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	22-Jan-24 11:15	3.3	---	0	0	---
7: TW Huronville South Treated Water	22-Jan-24 11:10	3.3	1.49	0	0	< 10
8: RW Murdock Glen Raw Water	22-Jan-24 11:45	3.3	---	0	0	---
9: TW Murdock Glen Treated Water	22-Jan-24 11:50	3.3	1.66	0	0	< 10
10: RW Blairs Grove Raw Water	22-Jan-24 12:10	3.3	---	0	0	---
11: TW Blairs Grove Treated Water	22-Jan-24 12:10	3.3	1.44	0	0	< 10
12: RW Point Clark Raw Water #2	22-Jan-24 12:50	3.3	---	0	0	---
13: RW Point Clark Raw Water #3	22-Jan-24 12:50	3.3	---	0	0	---
14: TW Point Clark Treated Water	22-Jan-24 12:40	3.3	1.80	0	0	< 10
15: DW DW Pt Clark CC	22-Jan-24 12:30	3.3	1.30	0	0	< 10
16: DW DW CH Inverlyn	22-Jan-24 11:00	3.3	1.32	0	0	< 10
17: DW DW Chem Shed	22-Jan-24 12:20	3.3	1.42	0	0	---
18: DW DW Amberley Beach St	22-Jan-24 13:05	3.3	1.65	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Crista Schuster
Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21007-JAN24

Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

19-January-2024

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 16 January 2024
LR Report: CA20718-JAN24

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	17-Jan-24	17-Jan-24	17-Jan-24
2: Analysis Start Time		---	---	09:30	09:30	09:10
3: Analysis Completed Date		---	---	19-Jan-24	19-Jan-24	19-Jan-24
4: Analysis Completed Time		---	---	10:33	10:33	10:33
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	15-Jan-24 12:18	8.9	---	0	0	---
7: TW Huronville South Treated Water	15-Jan-24 12:14	8.9	1.85	0	0	< 10
8: RW Murdock Glen Raw Water	15-Jan-24 15:55	8.9	---	0	0	---
9: TW Murdock Glen Treated Water	15-Jan-24 15:50	8.9	1.71	0	0	< 10
10: RW Blairs Grove Raw Water	15-Jan-24 14:53	8.9	---	0	0	---
11: TW Blairs Grove Treated Water	15-Jan-24 14:50	8.9	1.48	0	0	< 10
12: RW Point Clark Raw Water #2	15-Jan-24 13:44	8.9	---	0	0	---
13: RW Point Clark Raw Water #3	15-Jan-24 13:45	8.9	---	0	0	---
14: TW Point Clark Treated Water	15-Jan-24 13:40	8.9	1.78	0	0	< 10
15: DW DW - Amberley Beach SS	15-Jan-24 14:25	8.9	1.58	0	0	< 10
16: DW DW - Inverlyn Clubhouse	15-Jan-24 11:40	8.9	1.86	0	0	< 10
17: DW DW - Bruce Beach SS	15-Jan-24 15:30	8.9	1.58	0	0	---
18: DW DW - Chem Shed	15-Jan-24 15:05	8.9	1.53	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Crista Schuster
Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20718-JAN24

Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

12-January-2024

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 09 January 2024
LR Report: CA20456-JAN24

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1


Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	10-Jan-24	10-Jan-24	10-Jan-24
2: Analysis Start Time		---	---	14:45	14:45	14:20
3: Analysis Completed Date		---	---	11-Jan-24	11-Jan-24	12-Jan-24
4: Analysis Completed Time		---	---	17:30	17:30	12:27
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	09-Jan-24 10:15	9.6	---	0	0	---
7: TW Huronville South Treated Water	09-Jan-24 10:15	9.6	1.85	0	0	< 10
8: RW Murdock Glen Raw Water	09-Jan-24 09:45	9.6	---	0	0	---
9: TW Murdock Glen Treated Water	09-Jan-24 09:45	9.6	1.67	0	0	< 10
10: RW Blairs Grove Raw Water	09-Jan-24 09:15	9.6	---	0	0	---
11: TW Blairs Grove Treated Water	09-Jan-24 09:15	9.6	1.41	0	0	< 10
12: RW Point Clark Raw Water #2	09-Jan-24 09:00	9.6	---	0	0	---
13: RW Point Clark Raw Water #3	09-Jan-24 09:00	9.6	---	0	0	---
14: TW Point Clark Treated Water	09-Jan-24 08:55	9.6	1.64	0	0	< 10
15: DW DW - Amberley Beach SS	09-Jan-24 08:40	9.6	1.57	0	0	< 10
16: DW DW Chem Shed	09-Jan-24 09:10	9.6	1.35	0	0	< 10
17: DW DW Bruce Beach	09-Jan-24 09:35	9.6	1.32	0	0	---
18: DW DW Inverlyn	09-Jan-24 10:05	9.6	1.26	0	0	---

MAC - Maximum Acceptable Concentration



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20456-JAN24

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

05-January-2024

Veolia Water (Lakeshore)

Attn : Gary Nicholson

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Phone: 519-524-6583
Fax: 519-524-9358

Date Rec. : 02 January 2024
LR Report: CA20095-JAN24


Copy: #1

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	03-Jan-24	03-Jan-24	03-Jan-24
2: Analysis Start Time		---	---	13:15	13:15	12:50
3: Analysis Completed Date		---	---	05-Jan-24	05-Jan-24	05-Jan-24
4: Analysis Completed Time		---	---	09:41	09:41	11:29
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	02-Jan-24 11:15	8.6	---	0	0	---
7: TW Huronville South Treated Water	02-Jan-24 11:15	8.6	1.58	0	0	< 10
8: RW Murdock Glen Raw Water	02-Jan-24 11:45	8.6	---	0	0	---
9: TW Murdock Glen Treated Water	02-Jan-24 11:45	8.6	1.71	0	0	< 10
10: RW Blairs Grove Raw Water	02-Jan-24 12:00	8.6	---	0	0	---
11: TW Blairs Grove Treated Water	02-Jan-24 12:00	8.6	1.40	0	0	< 10
12: RW Point Clark Raw Water #2	02-Jan-24 12:25	8.6	---	0	0	---
13: RW Point Clark Raw Water #3	02-Jan-24 12:25	8.6	---	0	0	---
14: TW Point Clark Treated Water	02-Jan-24 12:30	8.6	1.66	0	0	< 10
15: DW DW - Amberley Beach SS	02-Jan-24 12:40	8.6	1.47	0	0	< 10
16: DW DW Inverlyn CH	02-Jan-24 11:00	8.6	1.08	0	0	< 10
17: DW DW Bruce Beach SS	02-Jan-24 11:30	8.6	1.38	0	0	---
18: DW DW Chem Shed	02-Jan-24 12:15	8.6	1.47	0	0	---

MAC - Maximum Acceptable Concentration



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

**SGS Canada Inc.**

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425**LR Report :** CA20095-JAN24

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001