

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

21-June-2024

Veolia Water (Lucknow)

Attn : Steve Walmsley

Date Rec. : 18 June 2024
 LR Report: CA20988-JUN24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				19-Jun-24	19-Jun-24	19-Jun-24
2: Analysis Start Time				09:40	09:40	09:15
3: Analysis Completed Date				21-Jun-24	21-Jun-24	21-Jun-24
4: Analysis Completed Time				09:50	09:50	09:50
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	17-Jun-24 13:45	15.5	---	0	0	---
7: TW Lucknow #4 Treated	17-Jun-24 13:50	15.5	1.51	0	0	< 10
8: RW Lucknow #5 Raw	17-Jun-24 14:05	15.5	---	0	0	---
9: TW Lucknow #5 Treated	17-Jun-24 14:05	15.5	1.53	0	0	< 10
10: DW 86667	17-Jun-24 13:30	15.5	1.35	0	0	< 10
11: DW Arena	17-Jun-24 13:40	15.5	1.00	0	0	20
12: DW Old Firehall	17-Jun-24 14:15	15.5	1.45	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

14-June-2024

Veolia Water (Lucknow)

Attn : Steve Walmsley

Date Rec. : 11 June 2024
 LR Report: CA20580-JUN24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				12-Jun-24	12-Jun-24	12-Jun-24
2: Analysis Start Time				10:10	10:10	09:30
3: Analysis Completed Date				14-Jun-24	14-Jun-24	14-Jun-24
4: Analysis Completed Time				09:36	09:36	09:36
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	10-Jun-24 13:58	7.8	---	0	0	---
7: TW Lucknow #4 Treated	10-Jun-24 14:00	7.8	1.48	0	0	< 10
8: RW Lucknow #5 Raw	10-Jun-24 14:55	7.8	---	0	0	---
9: TW Lucknow #5 Treated	10-Jun-24 14:50	7.8	1.53	0	0	10
10: DW LLS	10-Jun-24 14:25	7.8	1.36	0	0	< 10
11: DW 86667	10-Jun-24 15:15	7.8	1.35	0	0	< 10
12: DW Old Firehall	10-Jun-24 15:30	7.8	1.44	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

07-June-2024

Veolia Water (Lucknow)

Attn : Steve Walmsley

Date Rec. : 04 June 2024
 LR Report: CA20201-JUN24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				05-Jun-24	05-Jun-24	05-Jun-24
2: Analysis Start Time				09:45	09:45	09:20
3: Analysis Completed Date				07-Jun-24	07-Jun-24	07-Jun-24
4: Analysis Completed Time				09:56	09:56	09:56
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	03-Jun-24 15:00	8.6	---	0	0	---
7: TW Lucknow #4 Treated	03-Jun-24 14:55	8.6	1.54	0	0	< 10
8: RW Lucknow #5 Raw	03-Jun-24 14:00	8.6	---	0	0	---
9: TW Lucknow #5 Treated	03-Jun-24 13:55	8.6	1.64	0	0	< 10
10: DW LLS	03-Jun-24 13:30	8.6	1.36	0	0	< 10
11: DW 86667	03-Jun-24 15:20	8.6	1.41	0	0	< 10
12: DW Old Firehall	03-Jun-24 15:35	8.6	1.54	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SP-CA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

31-May-2024

Veolia Water (Lucknow)

Attn : Steve Walmsley

Date Rec. : 28 May 2024
 LR Report: CA21475-MAY24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	29-May-24	29-May-24	29-May-24
2: Analysis Start Time		---	---	09:40	09:40	09:15
3: Analysis Completed Date		---	---	31-May-24	31-May-24	31-May-24
4: Analysis Completed Time		---	---	11:20	11:20	11:20
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	27-May-24 13:05	12.1	---	0	0	---
7: TW Lucknow #4 Treated	27-May-24 13:05	12.1	1.64	0	0	20
8: RW Lucknow #5 Raw	27-May-24 13:20	12.1	---	0	0	---
9: TW Lucknow #5 Treated	27-May-24 13:25	12.1	1.66	0	0	< 10
10: DW 86667	27-May-24 12:45	12.1	1.29	0	0	< 10
11: DW Arena	27-May-24 12:55	12.1	0.98	0	0	40
12: DW Old Firehall	27-May-24 13:40	12.1	1.71	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

24-May-2024

Veolia Water (Lucknow)

Attn : Steve Walmsley

Date Rec. : 21 May 2024
 LR Report: CA21020-MAY24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	22-May-24	22-May-24	22-May-24
2: Analysis Start Time		---	---	12:10	12:10	11:45
3: Analysis Completed Date		---	---	24-May-24	24-May-24	24-May-24
4: Analysis Completed Time		---	---	12:09	12:09	12:09
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	21-May-24 12:30	12.9	---	0	0	---
7: TW Lucknow #4 Treated	21-May-24 12:35	12.9	1.70	0	0	< 10
8: RW Lucknow #5 Raw	21-May-24 12:20	12.9	---	0	0	---
9: TW Lucknow #5 Treated	21-May-24 12:15	12.9	1.68	0	0	< 10
10: DW 86667	21-May-24 11:55	12.9	1.45	0	0	< 10
11: DW Arena	21-May-24 12:05	12.9	1.33	0	0	< 10
12: DW Old Firehall	21-May-24 12:55	12.9	1.65	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

17-May-2024

Veolia Water (Lucknow)

Attn : Steve Walmsley

Date Rec. : 14 May 2024
 LR Report: CA20748-MAY24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	15-May-24	15-May-24	15-May-24
2: Analysis Start Time		---	---	---	09:45	09:45	09:05
3: Analysis Completed Date		---	---	---	17-May-24	17-May-24	17-May-24
4: Analysis Completed Time		---	---	---	12:31	12:31	12:31
5: MAC		---	---	---	0	0	---
6: RW Lucknow #4 Raw	13-May-24 14:00	9.1	---	0.19	0	0	---
7: TW Lucknow #4 Treated	13-May-24 14:00	9.1	1.77	0.23	0	0	< 10
8: RW Lucknow #5 Raw	13-May-24 13:20	9.1	---	0.20	0	0	---
9: TW Lucknow #5 Treated	13-May-24 13:20	9.1	1.65	0.22	0	0	< 10
10: DW LLS	13-May-24 13:10	9.1	1.43	---	0	0	< 10
11: DW 86667	13-May-24 13:45	9.1	1.49	---	0	0	< 10
12: DW LET	13-May-24 13:55	9.1	1.54	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

10-May-2024

Veolia Water (Lucknow)

Attn : Steve Walmsley

Date Rec. : 07 May 2024
 LR Report: CA20370-MAY24

100 Cove Rd., Goderich
 Canada, N7A 3Z2
 Phone: 519-524-6583, Fax:519-524-9358

Copy: #1

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	08-May-24	08-May-24	08-May-24
2: Analysis Start Time		---	---	09:50	09:50	09:25
3: Analysis Completed Date		---	---	10-May-24	10-May-24	10-May-24
4: Analysis Completed Time		---	---	10:01	10:01	10:01
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	06-May-24 15:30	11.3	---	0	0	---
7: TW Lucknow #4 Treated	06-May-24 15:25	11.3	1.80	0	0	< 10
8: RW Lucknow #5 Raw	06-May-24 15:50	11.3	---	0	0	---
9: TW Lucknow #5 Treated	06-May-24 15:45	11.3	1.58	0	0	< 10
10: DW 86667	06-May-24 15:10	11.3	1.31	0	0	< 10
11: DW Arena	06-May-24 15:20	11.3	1.25	0	0	< 10
12: DW Firehall	06-May-24 15:00	11.3	1.54	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

03-May-2024

Veolia Water (Lucknow)

Attn : Steve Walmsley

Date Rec. : 30 April 2024
 LR Report: CA20002-MAY24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				01-May-24	01-May-24	01-May-24
2: Analysis Start Time				09:55	09:55	09:10
3: Analysis Completed Date				03-May-24	03-May-24	03-May-24
4: Analysis Completed Time				11:13	11:13	11:13
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	29-Apr-24 14:05	10.7	---	0	0	---
7: TW Lucknow #4 Treated	29-Apr-24 13:55	10.7	1.73	0	0	< 10
8: RW Lucknow #5 Raw	29-Apr-24 14:55	10.7	---	0	0	---
9: TW Lucknow #5 Treated	29-Apr-24 14:50	10.7	1.68	0	0	< 10
10: DW LLS	29-Apr-24 14:25	10.7	1.52	0	0	< 10
11: DW 86667	29-Apr-24 15:05	10.7	1.62	0	0	< 10
12: DW Old Firehall	29-Apr-24 15:15	10.7	1.65	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SP-CA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

26-April-2024

Veolia Water (Lucknow)

Attn : Steve Walmsley

Date Rec. : 23 April 2024
 LR Report: CA21233-APR24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				24-Apr-24	24-Apr-24	24-Apr-24
2: Analysis Start Time				10:15	10:15	09:45
3: Analysis Completed Date				26-Apr-24	26-Apr-24	26-Apr-24
4: Analysis Completed Time				10:02	10:02	10:02
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	22-Apr-24 13:00	6.3	---	0	0	---
7: TW Lucknow #4 Treated	22-Apr-24 13:05	6.3	1.69	0	0	10
8: RW Lucknow #5 Raw	22-Apr-24 13:40	6.3	---	0	0	---
9: TW Lucknow #5 Treated	22-Apr-24 13:43	6.3	1.63	0	0	< 10
10: DW 86667	22-Apr-24 13:50	6.3	1.47	0	0	10
11: DW Old Firehall	22-Apr-24 14:00	6.3	1.56	0	0	< 10
12: DW LLS	22-Apr-24 13:25	6.3	1.55	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

19-April-2024

Veolia Water (Lucknow)

Attn : Steve Walmsley

Date Rec. : 16 April 2024
 LR Report: CA20837-APR24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				17-Apr-24	17-Apr-24	17-Apr-24
2: Analysis Start Time				14:05	14:05	13:40
3: Analysis Completed Date				19-Apr-24	19-Apr-24	19-Apr-24
4: Analysis Completed Time				14:15	14:15	14:15
5: MAC		---	---	0	0	---
6: DW Old Firehall	16-Apr-24 12:30	12.8	1.50	0	0	< 10
7: DW LLS	16-Apr-24 12:50	12.8	1.40	0	0	< 10
8: DW LCBO	16-Apr-24 13:10	12.8	1.32	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

19-April-2024

Veolia Water (Lucknow)

Attn : Steve Walmsley

Date Rec. : 16 April 2024
 LR Report: CA20823-APR24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	17-Apr-24	17-Apr-24	17-Apr-24
2: Analysis Start Time		---	---	---	12:10	12:10	12:00
3: Analysis Completed Date		---	---	---	19-Apr-24	19-Apr-24	19-Apr-24
4: Analysis Completed Time		---	---	---	11:30	11:30	11:30
5: MAC		---	---	---	0	0	---
6: RW Lucknow #4 Raw	15-Apr-24 13:05	12.8	---	0.23	0	0	---
7: TW Lucknow #4 Treated	15-Apr-24 13:05	12.8	1.66	0.27	0	0	< 10
8: RW Lucknow #5 Raw	15-Apr-24 13:30	12.8	---	0.25	1	1	---
9: TW Lucknow #5 Treated	15-Apr-24 13:30	12.8	1.51	0.29	0	0	< 10
10: RESAMPLE DW Old FireHall	15-Apr-24 12:15	12.8	1.39	---	0	0	< 10
11: DW LLS - Down	15-Apr-24 12:45	12.8	1.37	---	0	0	< 10
12: DW LLBO - Up	15-Apr-24 12:50	12.8	1.24	---	0	0	---
13: DW 86667	15-Apr-24 13:15	12.8	1.39	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code	Reference Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001	OMOE MICROMFDC-E3407A
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002	SM 9215C
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001	OMOE MICROMFDC-E3407A

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

15-April-2024

Veolia Water (Lucknow)

Attn : Steve Walmsley

Date Rec. : 12 April 2024
 LR Report: CA20623-APR24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #2

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				12-Apr-24	12-Apr-24	12-Apr-24
2: Analysis Start Time				11:40	11:40	11:15
3: Analysis Completed Date				15-Apr-24	15-Apr-24	15-Apr-24
4: Analysis Completed Time				10:12	10:12	10:12
5: MAC		---	---	0	0	---
6: RESAMPLE DW Firehall	11-Apr-24 11:08	10.8	1.43	0	0	< 10
7: DW LLS	11-Apr-24 11:20	10.8	1.36	0	0	< 10
8: DW LCBO	11-Apr-24 11:32	10.8	1.43	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code	Reference Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001	OMOE MICROMFDC-E3407A
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002	SM 9215C
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001	OMOE MICROMFDC-E3407A

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

12-April-2024

Veolia Water (Lucknow)

Attn : Steve Walmsley

Date Rec. : 09 April 2024
 LR Report: CA20471-APR24

100 Cove Rd., Goderich
 Canada, N7A 3Z2
 Phone: 519-524-6583, Fax:519-524-9358

Copy: #1

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	10-Apr-24	10-Apr-24	10-Apr-24
2: Analysis Start Time		---	---	09:40	09:40	09:08
3: Analysis Completed Date		---	---	12-Apr-24	12-Apr-24	12-Apr-24
4: Analysis Completed Time		---	---	11:25	11:25	11:25
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	08-Apr-24 13:55	7.4	---	0	0	---
7: TW Lucknow #4 Treated	08-Apr-24 14:00	7.4	1.61	0	0	< 10
8: RW Lucknow #5 Raw	08-Apr-24 13:30	7.4	---	0	0	---
9: TW Lucknow #5 Treated	08-Apr-24 13:30	7.4	1.50	0	0	< 10
10: DW DW 86667 Ross	08-Apr-24 13:00	7.4	1.49	0	0	10
11: DW DW Arena	08-Apr-24 13:10	7.4	1.31	0	0	< 10
12: DW DW Old Fire Hall	08-Apr-24 15:30	7.4	1.48	1 MAC	1 MAC	---

MAC - Maximum Acceptable Concentration
 MAC - (ADVERSE) Above Maximum Acceptable Concentration

The AWQI # assigned by the MOECP for the adverse result is: 164789

Method Descriptions

Units	Description	SGS Method Code	Reference Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001	OMOE MICROMFDC-E3407A
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002	SM 9215C
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001	OMOE MICROMFDC-E3407A

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

05-April-2024

Veolia Water (Lucknow)

Attn : Steve Walmsley

Date Rec. : 02 April 2024
 LR Report: CA20097-APR24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	03-Apr-24	03-Apr-24	03-Apr-24
2: Analysis Start Time		---	---	10:15	10:15	09:50
3: Analysis Completed Date		---	---	05-Apr-24	05-Apr-24	05-Apr-24
4: Analysis Completed Time		---	---	10:04	10:04	10:04
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	01-Apr-24 12:50	6.0	---	0	0	---
7: TW Lucknow #4 Treated	01-Apr-24 12:50	6.0	1.71	0	0	< 10
8: RW Lucknow #5 Raw	01-Apr-24 13:20	6.0	---	0	0	---
9: TW Lucknow #5 Treated	01-Apr-24 13:15	6.0	1.55	0	0	< 10
10: DW DW Arena	01-Apr-24 13:30	6.0	1.47	0	0	< 10
11: DW DW 86667 Lucknow	01-Apr-24 13:40	6.0	1.57	0	0	< 10
12: DW DW Old Firehall	01-Apr-24 13:05	6.0	1.85	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

01-April-2024

Veolia Water (Lucknow)

Attn : Steve Walmsley

Date Rec. : 26 March 2024
 LR Report: CA21102-MAR24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				27-Mar-24	27-Mar-24	27-Mar-24
2: Analysis Start Time				10:00	10:00	09:35
3: Analysis Completed Date				28-Mar-24	28-Mar-24	30-Mar-24
4: Analysis Completed Time				17:32	17:32	14:36
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	25-Mar-24 13:20	9.2	---	0	0	---
7: TW Lucknow #4 Treated	25-Mar-24 13:20	9.2	1.65	0	0	< 10
8: RW Lucknow #5 Raw	25-Mar-24 13:40	9.2	---	0	0	---
9: TW Lucknow #5 Treated	25-Mar-24 13:35	9.2	1.58	0	0	< 10
10: DW DW Old Firehall	25-Mar-24 13:00	9.2	1.62	0	0	< 10
11: DW DW LET	25-Mar-24 13:15	9.2	1.51	0	0	< 10
12: DW DW 86661	25-Mar-24 13:05	9.2	1.60	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

22-March-2024

Veolia Water (Lucknow)

Attn : Steve Walmsley

Date Rec. : 19 March 2024
 LR Report: CA20809-MAR24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				20-Mar-24	20-Mar-24	20-Mar-24
2: Analysis Start Time				09:50	09:50	09:20
3: Analysis Completed Date				22-Mar-24	22-Mar-24	22-Mar-24
4: Analysis Completed Time				11:23	11:23	11:23
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	18-Mar-24 13:48	9.2	---	0	0	---
7: TW Lucknow #4 Treated	18-Mar-24 13:45	9.2	1.59	0	0	30
8: RW Lucknow #5 Raw	18-Mar-24 14:27	9.2	---	0	0	---
9: TW Lucknow #5 Treated	18-Mar-24 14:20	9.2	1.65	0	0	< 10
10: DW DW LLS	18-Mar-24 14:10	9.2	1.55	0	0	< 10
11: DW DW 86667	19-Mar-24 08:10	9.2	1.63	0	0	< 10
12: DW DW Old Firehall	19-Mar-24 08:25	9.2	1.69	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

15-March-2024

Veolia Water (Lucknow)

Attn : Steve Walmsley

Date Rec. : 12 March 2024
 LR Report: CA20495-MAR24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				13-Mar-24	13-Mar-24	13-Mar-24
2: Analysis Start Time				10:10	10:10	09:35
3: Analysis Completed Date				15-Mar-24	15-Mar-24	15-Mar-24
4: Analysis Completed Time				10:20	10:20	10:20
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	11-Mar-24 13:10	9.2	---	0	0	---
7: TW Lucknow #4 Treated	11-Mar-24 13:10	9.2	1.65	0	0	< 10
8: RW Lucknow #5 Raw	11-Mar-24 13:25	9.2	---	0	0	---
9: TW Lucknow #5 Treated	11-Mar-24 13:25	9.2	1.61	0	0	< 10
10: DW DW Old Firehall	11-Mar-24 13:45	9.2	1.53	0	0	< 10
11: DW DW LET	11-Mar-24 13:05	9.2	1.57	0	0	70
12: DW DW 86667	11-Mar-24 12:55	9.2	1.67	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

08-March-2024

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 05 March 2024
 LR Report: CA20200-MAR24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	06-Mar-24	06-Mar-24	06-Mar-24
2: Analysis Start Time		---	---	09:45	09:45	09:20
3: Analysis Completed Date		---	---	08-Mar-24	08-Mar-24	08-Mar-24
4: Analysis Completed Time		---	---	10:42	10:42	10:42
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	04-Mar-24 13:45	8.5	---	0	0	---
7: TW Lucknow #4 Treated	04-Mar-24 13:40	8.5	1.87	0	0	10
8: RW Lucknow #5 Raw	04-Mar-24 14:30	8.5	---	0	0	---
9: TW Lucknow #5 Treated	04-Mar-24 14:25	8.5	1.74	0	0	< 10
10: DW DW Firehall	04-Mar-24 13:55	8.5	1.69	0	0	< 10
11: DW DW 86667	04-Mar-24 14:50	8.5	1.68	0	0	10
12: DW DW LLS	04-Mar-24 14:05	8.5	1.61	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

01-March-2024

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 27 February 2024
LR Report: CA21078-FEB24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				28-Feb-24	28-Feb-24	28-Feb-24
2: Analysis Start Time				09:30	09:30	09:10
3: Analysis Completed Date				01-Mar-24	01-Mar-24	01-Mar-24
4: Analysis Completed Time				10:10	10:10	10:10
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	26-Feb-24 14:05	7.3	---	0	0	---
7: TW Lucknow #4 Treated	26-Feb-24 14:00	7.3	1.84	0	0	< 10
8: RW Lucknow #5 Raw	26-Feb-24 14:45	7.3	---	0	0	---
9: TW Lucknow #5 Treated	26-Feb-24 14:40	7.3	1.73	0	0	< 10
10: DW DW LLS	26-Feb-24 14:20	7.3	1.61	0	0	< 10
11: DW DW 86667	26-Feb-24 14:55	7.3	1.67	0	0	< 10
12: DW DW L Firehall	26-Feb-24 15:05	7.3	1.60	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

23-February-2024

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 20 February 2024
LR Report: CA20730-FEB24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	21-Feb-24	21-Feb-24	21-Feb-24
2: Analysis Start Time		---	---	10:35	10:35	10:10
3: Analysis Completed Date		---	---	23-Feb-24	23-Feb-24	23-Feb-24
4: Analysis Completed Time		---	---	11:12	11:12	11:12
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	20-Feb-24 14:35	8.1	---	0	0	---
7: TW Lucknow #4 Treated	20-Feb-24 14:35	8.1	1.82	0	0	< 10
8: RW Lucknow #5 Raw	20-Feb-24 13:25	8.1	---	0	0	---
9: TW Lucknow #5 Treated	20-Feb-24 13:25	8.1	1.65	0	0	< 10
10: DW DW 86667 Ross	20-Feb-24 13:00	8.1	1.57	0	0	< 10
11: DW DW Firehall	20-Feb-24 14:45	8.1	1.47	0	0	< 10
12: DW DW Arena	20-Feb-24 12:55	8.1	1.51	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

16-February-2024

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 13 February 2024
 LR Report: CA20498-FEB24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	14-Feb-24	14-Feb-24	14-Feb-24
2: Analysis Start Time		---	---	10:30	10:30	09:55
3: Analysis Completed Date		---	---	16-Feb-24	16-Feb-24	16-Feb-24
4: Analysis Completed Time		---	---	11:03	11:03	11:03
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	12-Feb-24 15:20	5.0	---	0	0	---
7: TW Lucknow #4 Treated	12-Feb-24 15:20	5.0	1.85	0	0	< 10
8: RW Lucknow #5 Raw	12-Feb-24 15:35	5.0	---	0	0	---
9: TW Lucknow #5 Treated	12-Feb-24 15:30	5.0	1.60	0	0	< 10
10: DW DW Old Firehall	12-Feb-24 15:55	5.0	1.55	0	0	< 10
11: DW DW LET	12-Feb-24 15:05	5.0	1.63	0	0	< 10
12: DW DW 86667	12-Feb-24 14:55	5.0	1.55	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

09-February-2024

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 06 February 2024
LR Report: CA20221-FEB24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				07-Feb-24	07-Feb-24	07-Feb-24
2: Analysis Start Time				10:00	10:00	09:35
3: Analysis Completed Date				09-Feb-24	09-Feb-24	09-Feb-24
4: Analysis Completed Time				11:08	11:08	11:08
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	05-Feb-24 14:10	2.8	---	0	0	---
7: TW Lucknow #4 Treated	05-Feb-24 14:10	2.8	1.62	0	0	< 10
8: RW Lucknow #5 Raw	05-Feb-24 13:45	2.8	---	0	0	---
9: TW Lucknow #5 Treated	05-Feb-24 13:45	2.8	1.69	0	0	< 10
10: DW DW 86667 Ross St	05-Feb-24 13:30	2.8	1.43	0	0	< 10
11: DW DW Fire Hall	05-Feb-24 14:40	2.8	1.44	0	0	< 10
12: DW DW Arena	05-Feb-24 13:25	2.8	1.42	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

02-February-2024

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 30 January 2024
 LR Report: CA21266-JAN24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	31-Jan-24	31-Jan-24	31-Jan-24
2: Analysis Start Time		---	---	12:00	12:00	11:40
3: Analysis Completed Date		---	---	02-Feb-24	02-Feb-24	02-Feb-24
4: Analysis Completed Time		---	---	11:31	11:31	11:31
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	30-Jan-24 10:55	5.0	---	0	0	---
7: TW Lucknow #4 Treated	30-Jan-24 10:55	5.0	1.69	0	0	< 10
8: RW Lucknow #5 Raw	30-Jan-24 11:15	5.0	---	0	0	---
9: TW Lucknow #5 Treated	30-Jan-24 11:10	5.0	1.78	0	0	< 10
10: DW DW 86667 Ross	30-Jan-24 10:30	5.0	1.53	0	0	< 10
11: DW DW Arena	30-Jan-24 10:40	5.0	1.65	0	0	< 10
12: DW DW Old Fire Hall	30-Jan-24 10:35	5.0	1.65	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

26-January-2024

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 23 January 2024
LR Report: CA21006-JAN24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	24-Jan-24	24-Jan-24	24-Jan-24
2: Analysis Start Time		---	---	09:45	09:45	09:15
3: Analysis Completed Date		---	---	26-Jan-24	26-Jan-24	26-Jan-24
4: Analysis Completed Time		---	---	10:10	10:10	10:10
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	22-Jan-24 13:30	3.3	---	0	0	---
7: TW Lucknow #4 Treated	22-Jan-24 13:30	3.3	1.68	0	0	< 10
8: RW Lucknow #5 Raw	22-Jan-24 13:40	3.3	---	0	0	---
9: TW Lucknow #5 Treated	22-Jan-24 13:40	3.3	1.71	0	0	< 10
10: DW DW Old Firehall	22-Jan-24 13:00	3.3	1.71	0	0	< 10
11: DW DW LET	22-Jan-24 13:20	3.3	1.50	0	0	10
12: DW DW 86667	22-Jan-24 13:15	3.3	1.69	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SP-CA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

19-January-2024

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 16 January 2024
LR Report: CA20728-JAN24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	17-Jan-24	17-Jan-24	17-Jan-24
2: Analysis Start Time		---	---	---	12:25	12:25	11:50
3: Analysis Completed Date		---	---	---	19-Jan-24	19-Jan-24	19-Jan-24
4: Analysis Completed Time		---	---	---	11:01	11:01	11:01
5: MAC		---	---	---	0	0	---
6: RW Lucknow #4 Raw	16-Jan-24 11:25	8.9	---	0.22	0	0	---
7: TW Lucknow #4 Treated	16-Jan-24 11:20	8.9	1.75	---	0	0	< 10
8: RW Lucknow #5 Raw	16-Jan-24 12:05	8.9	---	0.19	0	0	---
9: TW Lucknow #5 Treated	16-Jan-24 12:00	8.9	1.83	---	0	0	< 10
10: DW DW 86667 Ross St (ACW)	16-Jan-24 11:00	8.9	1.61	---	0	0	< 10
11: DW DW Arena	16-Jan-24 10:45	8.9	1.53	---	0	0	< 10
12: DW DW LLS	16-Jan-24 11:35	8.9	1.45	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

12-January-2024

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 09 January 2024
 LR Report: CA20451-JAN24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	10-Jan-24	10-Jan-24	10-Jan-24
2: Analysis Start Time		---	---	10:10	10:10	09:45
3: Analysis Completed Date		---	---	11-Jan-24	11-Jan-24	12-Jan-24
4: Analysis Completed Time		---	---	16:07	16:07	11:29
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	08-Jan-24 14:00	9.6	---	0	0	---
7: TW Lucknow #4 Treated	08-Jan-24 13:55	9.6	1.50	0	0	< 10
8: RW Lucknow #5 Raw	08-Jan-24 13:32	9.6	---	0	0	---
9: TW Lucknow #5 Treated	08-Jan-24 13:35	9.6	1.60	0	0	< 10
10: DW DW Arena	08-Jan-24 14:10	9.6	1.42	0	0	< 10
11: DW DW 86667	08-Jan-24 14:25	9.6	1.50	0	0	< 10
12: DW DW LLS	08-Jan-24 13:15	9.6	1.60	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

05-January-2024

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 02 January 2024
LR Report: CA20091-JAN24

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				03-Jan-24	03-Jan-24	03-Jan-24
2: Analysis Start Time				14:15	14:15	13:50
3: Analysis Completed Date				05-Jan-24	05-Jan-24	05-Jan-24
4: Analysis Completed Time				12:49	12:49	12:49
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	02-Jan-24 09:40	8.6	---	0	0	---
7: TW Lucknow #4 Treated	02-Jan-24 09:40	8.6	1.65	0	0	< 10
8: RW Lucknow #5 Raw	02-Jan-24 09:55	8.6	---	0	0	---
9: TW Lucknow #5 Treated	02-Jan-24 09:55	8.6	1.77	0	0	< 10
10: DW DW LLS	02-Jan-24 09:20	8.6	1.48	0	0	< 10
11: DW DW LET	02-Jan-24 09:35	8.6	1.50	0	0	< 10
12: DW DW 66667	02-Jan-24 09:25	8.6	1.53	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SP-CA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety