

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

31-January-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

Date Rec. : 28 January 2025
 LR Report: CA21226-JAN25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				29-Jan-25	29-Jan-25	29-Jan-25
2: Analysis Start Time				16:00	16:00	15:35
3: Analysis Completed Date				31-Jan-25	31-Jan-25	31-Jan-25
4: Analysis Completed Time				13:07	13:07	13:07
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	28-Jan-25 08:26	6.8	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	28-Jan-25 08:19	6.8	---	0	0	---
8: TW TW-Whitechurch TW	28-Jan-25 08:14	6.8	1.45	0	0	< 10
9: DW DW-East Whitechurch DW-SS	28-Jan-25 08:04	6.8	1.42	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

24-January-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

Date Rec. : 21 January 2025
 LR Report: CA20941-JAN25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				22-Jan-25	22-Jan-25	22-Jan-25
2: Analysis Start Time				16:20	16:20	15:45
3: Analysis Completed Date				24-Jan-25	24-Jan-25	24-Jan-25
4: Analysis Completed Time				14:18	14:18	14:18
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	21-Jan-25 09:12	4.9	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	21-Jan-25 09:20	4.9	---	0	0	---
8: TW TW-Whitechurch TW	21-Jan-25 09:15	4.9	1.51	0	0	< 10
9: DW DW-East Whitechurch DW-SS	21-Jan-25 08:13	4.9	1.33	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

17-January-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

Date Rec. : 14 January 2025
 LR Report: CA20583-JAN25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				15-Jan-25	15-Jan-25	15-Jan-25
2: Analysis Start Time				15:00	15:00	14:35
3: Analysis Completed Date				17-Jan-25	17-Jan-25	17-Jan-25
4: Analysis Completed Time				12:42	12:42	12:42
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	14-Jan-25 10:33	6.0	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	14-Jan-25 10:17	6.0	---	0	0	---
8: TW TW-Whitechurch TW	14-Jan-25 10:13	6.0	1.54	0	0	< 10
9: DW DW-East Whitechurch DW-SS	14-Jan-25 09:57	6.0	1.34	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

13-January-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

Date Rec. : 08 January 2025
 LR Report: CA20303-JAN25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	08-Jan-25	08-Jan-25	08-Jan-25
2: Analysis Start Time		---	---	18:50	18:50	18:20
3: Analysis Completed Date		---	---	10-Jan-25	10-Jan-25	10-Jan-25
4: Analysis Completed Time		---	---	17:40	17:40	17:40
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	07-Jan-25 10:09	3.4	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	07-Jan-25 10:23	3.4	---	0	0	---
8: TW TW-Whitechurch TW	07-Jan-25 10:17	3.4	1.56	0	0	< 10
9: DW DW-East Whitechurch DW-SS	07-Jan-25 10:00	3.4	1.14	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


 Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety